6753 Low Pressure Airswitch




Technology Ltd

- Sensitive versatile switch, ideal for long tube lengths
- Ideal for switching low power circuits
- Temperature compensated versions available


• Easily adjustable settings



Reference Dimensions mm



Ordering & Options





6753 Low Pressure Airswitch



Technology Ltd

General specifications		
Standards/approvals	UL 508 specific models only	
Degree of protection	n/a	
Connection method	Via back entry spout, Ø4 mm	
Electrical rating	0.5A 250V AC	
Contact configuration	SPST, N/O or N/C	

Pressure range	n/a
Operating temperature range	-5°C to +40°C
Body material	Thermoplastic
Weight	0.01 kg
Additional information	

6753 - Range options and technical data

Body withstand pressure	mbar	1,000
Pressure connection		Ø4 mm spout Pressure or vacuum spout side varies according to contact configuration
Connecting tube reference		2311-08 or 2311-01 to suit Ø4mm
Diaphragm		Neoprene
Mechanical life		1 x 10 ⁶ cycles

Electrical data		
Contact configuration		SPST N/O or N/C
Contact plating		Gold or Silver
Contact rating	Max.	0.5A 250 V AC
Dry switching current	Min.	5 mA 4 VDC
Contact resistance	Ω	0.05


The 6753 range of switches provide a high specification in a small, versatile body shell. Great care has been taken in the switch unit design keeping the moving mass and therefore inertia to a minimum. This means that it can operate at a high cycle rate with low pressure or vacuum.

When measuring pressure pulses such as on component counting applications, the switch will operate very rapidly due to the low inertia of the moving parts and the low swept volume.

For good repeatable switching, the contacts are gold plated on solid silver. The operating pressure will have a direct effect on the contact pressure; therefore at very low pressures the maximum contact rating will not be achieved.

For a normally open switch the contacts can be closed either by applying pressure at port B or vacuum at port A.

For a normally closed switch, the contacts can be opened either by applying pressure at port A or vacuum at port B.



Where temperature compensation is required, consider carefully which side of the moving contact the bleed should be fitted. This will vary dependant on pressure or vacuum operation.