

TRANSDUCER OF DIRECT CURRENT NETWORK PARAMETERS **P30H**



USER'S MANUAL



Contents

1. Application.....	3
2. Transducer set.....	5
3. Basic requirements, operational safety.....	5
4. Installation.....	7
4.1. Mounting.....	7
4.2. External connection diagrams.....	8
5. Service.....	10
5.1. Description of P30H transducer's frontal plate.....	10
5.2. Power-on messages.....	11
5.3. Functions of the buttons.....	12
5.3.1. Functions of single buttons.....	12
5.3.2. Functions of button combinations.....	14
5.3.3. Programming matrix.....	15
5.4. Programming parameters of the transducer.....	16
5.4.1. Type of selected parameter value change.....	18
5.4.2. Changing the floating-point values.....	19
5.4.3. Programmable parameters of the transducer.....	19
5.5. Functions of the transducer.....	33
5.5.1. Measuring input.....	33
5.5.1.1 Averaging time of instantaneous values.....	33
5.5.1.2 Mean values, synchronized with the clock.....	34
5.5.1.3 Maximum and minimum values displayed.....	34
5.5.1.4. Transducer configuration example for control of charging lead acid battery.....	35
5.5.2. Analog outputs.....	38
5.5.2.1. Individual characteristic of analog outputs.....	38
5.5.2.2 Analog outputs overrun support.....	39
5.5.3 Alarm and power outputs.....	43
5.5.4 LCD display.....	44
5.5.5 Saving and reading transducer configuration file.....	49
5.5.5.1 Saving transducer configuration file.....	49
5.5.5.2 Reading transducer configuration file.....	49
5.6. Default settings.....	51
5.7. Software upgrades.....	54
5.8. Measuring values archiving.....	56
5.8.1 Transducer memory structure.....	56
5.8.2 Internal memory.....	57
5.8.2.1 Structure of the record	58
5.8.2.2. Acquisition of archived data from the internal memory.....	59
5.8.3 Archiving configuration.....	61
5.8.4 Memory card or internal memory file system (optional).....	62
5.8.5 Archive files structure.....	65
5.9. RS-485 interface.....	65
5.9.1 Connection of the serial interface.....	66
5.9.2 Description of the MODBUS protocol implementation.....	67
5.9.3 Description of the implemented functions.....	68
5.9.4 Interface RS-485 Master mode.....	72
5.9.5 Interface RS-485 Monitor mode.....	74
5.9.6 Map of the registers.....	76
5.9.7 Registers for writing and readout.....	78
5.9.8 Registers for readout.....	94
5.10. Ethernet interface 10/100-BASE-T.....	104
5.10.1 Connecting 10/100-BASE-T interface.....	105
5.10.2 Web Server.....	107
5.10.2.1. General view.....	108
5.10.2.2. Web user selection.....	108
5.10.3 FTP Server.....	110
5.10.3.1. FTP user selection.....	110

5.10.4 Modbus TCP/IP 112

6. Accessories..... 112

6.1. Memory card..... 112

6.2. Additional resistor D5..... 113

7. Error codes..... 116

8. Technical data..... 117

9. Ordering code..... 123

1. Application

Programmable transducer P30H is suited for voltage, current (voltage measurement from a shunt) and power measurement in d.c. circuits and for conversion of measured value into a standard d.c. and a.c. signal. Output signal is galvanically insulated from input signal and power signal. Transducer uses 2x8 characters LCD.

Characteristics of P30H Transducer:

- conversion of measured values into an output signal on the base of the individual linear characteristic,
- one or two relay alarms with the n/o contact operating in 6 modes,
- 24 VDC 30 mA auxiliary power turned on/off according to program (optional)
- signaling of the set alarm values tripping,
- programming of alarm output and analog outputs reacting to the selected input value,
- real time clock with the clock power support function in case of the transducer power failure,
- input signal registration in the internal memory and SD/SDHC cards within the programmed time intervals (optional),
- internal memory with 534336 record capacity,
- automatic decimal point set,
- set parameters display,
- password protection for the input parameters,

- compatibility with RS-485 interface with MODBUS protocol, in RTU mode,
- measurement averaging time programming,
- SD/SDHC card use – FAT and FAT32 system compatibility,
- Master RS-485 mode – 1 device query,
- Ethernet interface 10/100 BASE-T (optional)
 - protocol: Modbus TCP/IP, HTTP, FTP,
 - services: web server, FTP server, DHCP client

The values measured and calculated by the transducer:

- ⇒ voltage + rescaling constant
- ⇒ current (as measured voltage at the shunt ± 150 mV) + rescaling constant
- ⇒ power
- ⇒ voltage difference in time 5 s, 30 s, 1 min, 5 min, 15 min (dU)
- ⇒ current difference in time 5 s, 30 s, 1 m, 5 m, 15 m (dI)
- ⇒ averaged voltage (eg. 15 min.)
- ⇒ averaged current (eg. 15 min.)
- ⇒ averaged power (eg. 15 min.)
- ⇒ time in seconds
- ⇒ time in hours and minutes
- ⇒ charge capacity in Ah
- ⇒ imported energy
- ⇒ exported energy
- ⇒ maximum and minimum values.

Transducer allows for the use of voltage and current rescaling constants, which will be included in the measurement and calculation of all measurement values. Value upgrade time does not exceed 1 second. All values and configuration parameters are available through RS-485 and Ethernet (Modbus protocol) (option).



Fig. 1 Appearance of P30H transducer different versions.

2. Transducer set

- P30H Transducer 1 pc
- user's manual 1 pc
- warranty card 1 pc
- plug with the screw terminals 2 pc

3. Basic requirements, operational safety

In the security scope, the transducer meets the requirements of the EN 61010-1 standard.

Comments concerning safety



- Assembly and installation of the electrical connections should be conducted only by people authorised to perform assembly of electric devices.

- Always check the connections before turning the transducer on.
- The transducer is designed to installation and usage in the industrial electromagnetic environment.
- A switch or a circuit-breaker should be installed in the building or facility. It should be located near the device, easily accessible by the operator, and suitably marked.
- Removal of the transducer housing during the warranty period voids the warranty.

4. Installation

4.1. Mounting

The P30 transducer are designed for installation on a 35 mm rail acc. to EN 60715. Overall dimensions and mounting is shown in Figure 2.




Fig.2 Overall dimensions and mounting of the transducer.

The output signals are galvanically isolated from the input signals and power supply.

The meter housing is made of plastic. On the outside two clamping strips that can accommodate cables up to 2.5 mm² in diameter.

4.2. External connection diagrams

Measured signal	Current, indirect measurment using external shunt on input. +/- 150 mV	Voltage direct measurement 12 V, 48 V, 100 V, 250 V	Power of d.c. current
Connection diagram			
	SUPP- power supply OUT3 - output no.3 (alarm or supplying output 24 V) OUT2 - output no.2 (alarm or analog output) OUT1 - main analog output no.1 INPUT - measuring input RS- 485 - RS-485 interface	P30H-XX11XXXXX OUT2 - alarm no.1 OUT3 - alarm no.2	P30H-XX21XXXXX OUT2 - analog output no.2 0/4...20 mA OUT3 - alarm no.2
Connection diagram		P30H-XX12XXXXX OUT2 - alarm no.1 OUT3 - supplying output 24 V d.c., 30 mA	P30H-XX22XXXXX OUT2 - analog output no.2 0/4...20 mA OUT3 - supplying output 24 V d.c., 30 mA
		P30H-XX31XXXXX OUT2 - analog output no.2 0...10 V OUT3 - alarm no.2	P30H-XX32XXXXX OUT2 - analog output no.2 0...10 V OUT3 - supplying output 24 V d.c., 30 mA

Note!

If you need to measure voltages higher than 300V d.c., must use an external additional resistor type D5 / 1 (600V) or D5 / 2 (1000V)

**Voltage,
indirect measurement
600 V,100 V**

For the measured voltage range 300...600V
P30H set with additional resistor D5 meets the
requirements:

- CAT III,
- basic isolation between input circuits (terminals 1-4) and other circuits (60s /3,51kV a.c.)

*For the measured voltage range
600...1000V P30H set with additional resistor D5
meets the requirements:*

- CAT II,
- basic isolation between input circuits (terminals 1-4) and other circuits (60s /3,51kV a.c.)




Fig.3 Wiring diagram of the P30H transducer

5. Service

5.1. Description of P30H transducer's frontal plate




Fig.4 Description of the transducer's frontal plate

Note: Memory card (optional) should be inserted into the transducer with contacts on the bottom side.

Description of LED indicator:

RX – green LED - indicator of data receiving on RS-485 link

TX – yellow LED - indicator of data transmission on RS-485 link

M – red LED – indicates reaching the limit of the internal archive memory and saving the data on the SD/SDHC card - when the internal memory is 95% full, LED is constantly on, if the transducer is using a memory card, LED is pulsating during the saving process until it is finished.

A1 – red LED – indicates engaging the first alarm

A2 – red LED – indicates engaging the second alarm or 24VDC power.

Power indicator – green LED

5.2. Power-on messages

After connecting the external signals and turning the power on accompanied by turning the green LED (power indicator) on, transducer displays the type, current software version and the serial number. If the transducer is equipped with Ethernet interface (P30H-XX2XXXXXXXXX), then after displaying the serial no., the device displays also the IP address saved in memory or received from DHCP server.

- P30H -	firm.ver 3.00	Serial 15020001
----------	------------------	--------------------

Fig.5 Starting messages of the transducer not equipped with Ethernet interface

- P30H -	firm.ver 3.00	Serial 15020001	IP:	192.168 001.030
----------	------------------	--------------------	-----	--------------------

Fig.6 Starting messages of the transducer equipped with Ethernet interface

The transducer automatically switches to the operating mode of

measurement and processing the analog output signal after approx. 3 seconds. Measured value is displayed in the upper line of the display, the additional information is displayed in the lower line, see 5.5.4).

LED display shows the RS-485 transmission status, internal memory usage and alarm status. Ethernet services (WWW server, FTP server, Modbus TCP/IP) are started for transducers equipped with Ethernet interface.

5.3. Functions of the buttons

5.3.1. Functions of single buttons




- confirm button

- entering the programming mode (hold the button for at least 3 seconds),
- menu item selection – level selection,
- entering the parameter value change mode,
- accepting the altered parameter value,
- change of content displayed on the bottom line of the display
- turning the transducer on and holding down the button - entering into software update mode via RS-485 interface, the link parameters: baud rate 9600 bit/s, 8N2 mode.



- increase value button

- change of the displayed value,
- navigation within selected level,
- change of the selected parameter value – value increase,


 - digit change button

- change of the displayed value
- moving to the parameter group level,
- navigation within selected level
- selected parameter value change – moving to subsequent number
- turning the transducer on and holding down the button - entering into software update mode via RS-485 interface, the link parameters: baud rate 115200 bit/s, 8N2 mode.

 - cancel button

- enters the transducer parameter display mode (hold the button for at least 3 seconds),
- quits the transducer parameter display menu
- change of content displayed on the bottom line of the display
- cancels the parameter change
- forced exit from the programming mode (hold the button for at least 3 seconds),
- turns the transducer with the button pressed – forces loading transducer configuration from the P30H_PAR.CON file saved to the external SD/SDHC card or internal file system memory (depends on the version).

5.3.2. Functions of button combinations

  - holding down for approx. 3 second

● deletes alarm signalization; this operation works only with support function turned on;

  - holding down for approx. 1 second

● displays maximum of the currently displayed value

  - holding down for approx. 1 second

● displays minimum of the currently displayed value



  - holding down for approx. 1 second


● unmounts the SD/SDHC card allowing it to be safely removed – for the transducers with external SD/SDHC card slot

  - holding down for approx. 1 second

● forces the rewriting of the archive from internal memory to the SD/SDHC card – for the transducers with external SD/SDHC card slot

● overrides the rewriting of the archive from internal memory to file system memory – for the transducers with Ethernet interface; this operation allows for the loading the files with current archive data from transducer via FTP protocol

  - holding down for approx. 3 seconds, deleting extremal values

Pressing and holding the button for approx. 3 seconds  causes exiting to the programming matrix. The programming matrix can be protected by an access code.

5.3.3. Programming matrix










Fig. 7 P30H Transducer service algorithm

5.4. Programming parameters of the transducer

Pressing the button  Pressing and holding down the button for approx. 3 seconds allows to exit to the programming matrix. If the output is password-protected, a password entry message will be displayed. If the entered password is incorrect, a following message appears: **Invalid Code**. Entering a valid password starts programming matrix. The Fig. 8. shows the transition matrix in the programming mode. Buttons allow the selection of the menu level and moving through the sublevel parameters  or . Parameter symbol is displayed in the upper display line, the parameter itself is displayed in the lower line. To edit a given parameter, press the following button: . To cancel the parameter change, press the following button: . To exit the programming matrix and enter the measurement mode, press and hold the following button: . If the transducer is left in the parameter programming mode, after 30 seconds it will exit programming mode and start to display the displayed value.





Settings Input	VoltRang	DemandTm	Averag.	I direct	Clear En	Reset AV	TempMeas	Rst.Coun	Syn.Time	DeltTime
Parameters of the main input	range of voltage measurement 12 / 48 / 100 / 250 V	method of averaging the mean values P, I, U	Averaging time of instantaneous values	Program possibility to reverse the current direction	Clear energy counter	Restart counting the average values	The choice of how to obtain temperature values	Timer reset	Selection of timer synchronization	Selecting the time to indicate the delta voltages and currents
	CurrThrs Current threshold above which time is counted	Primar.U Input voltage (included when calculating the rescaling ratio)	Second.U Output voltage (included when calculating the rescaling ratio)	Shunt I Shunt nominal current	Shunt mV The voltage corresponding to the nominal current shunt					



Settings Display	DecimalP	Bcklight	Bckl.Int								
Display parameters	Minimum decimal point	Time of a display panel illumination	Intensity of LCD display panel illumination								
Settings Alarm 1	Param.A1	Type A1	OverLoA1	OverHiA1	DlyOnA1	DlyOffA1	OnLockA1	SgKeepA1			
Alarm 1 parameters	Input value type for alarm 1	Alarm type 1	Alarm 1 lower limit	Alarm 1 upper limit	Alarm 1 activation delay	Alarm 1 deactivation delay	Alarm 1 re-activation delay	Alarm 1 signalization latch			
Settings Alarm 2	Param.A2	Type A2	OverLoA2	OverHiA2	DlyOnA2	DlyOffA2	OnLockA2	SgKeepA2			
Alarm 2 parameters	Input value type for alarm 1	Alarm type 2	Alarm 2 lower limit	Alarm 2 upper limit	Alarm 2 activation delay	Alarm 2 deactivation delay	Alarm 2 re-activation delay	Alarm 2 signalization latch			
Settings Output	ParamAn1	AnIn Lo1	AnIn Hi1	AnOutLo1	AnOutHi1	OverSer1	Parameters available only when the OverSer1 option is on				
							OvOutLo1	OvOutHi1	OvrOutL1	OvrOutH1	
							Output 1 lower limit overrun	Output 1 upper limit overrun	Output 1 expected value when the lower limit is exceeded	Output 1 expected value when the upper limit is exceeded	
							Enabling an overrun of output 1				
	ParamAn2	AnIn Lo2	AnIn Hi2	AnOutLo2	AnOutHi2	OverSer2	Parameters available only when the OverSer2 option is on				
							OvOutLo2	OvOutHi2	OvrOutL2	OvrOutH2	
							Output 2 lower limit overrun	Output 2 upper limit overrun	Output 2 expected value when the lower limit is exceeded	Output 2 expected value when the upper limit is exceeded	
							Enabling an overrun of output 2				
Settings Mbus 485	Address	ModeUnit	BaudRate	Base.Reg	No.ofVal	ValType	Interv.	AnswTime	Mode	Mast.Fun	
RS-485 interface parameters	Device address	Frame type	Baud rate	Base register number (Master mode)	Number of the queried values (Master mode)	Type of the queried values (Master mode)	Query period (Master mode)	Max. response time (Master mode)	Interface RS-485 operating mode	Selection of the function type for the interface operation in Master mode	
	No.OfErr										
	Allowed number of the failed queries for RS-485 Master mode										
Settings Archive	Arch.Val	Param.Ar	Ar. Mode	OverLoAr	OverHiAr	Ar. Time	Ar.Erase	Rec.ToSD	Param.SD		
Archiving parameters	Archived values selection	Value type triggerining conditional archiving	Archiving type	Archiving lower limit	Archiving upper limit	Archiving period	Deleting an internal archive	Override allowing for copying of the internal archive to SD/SDHC card	The percentage of the internal archive space used which triggers automatic writing on SD/SDHC card		

Settings Ethernet	DHCP	addrIP32	addrIP10	mask 32	mask 10	gate 32	gate 10	MAC 54	MAC 32	MAC 10
	Enable/disable DHCP client	B3,B2 byte of IP address (IPv4)	B1,B0 byte of IP address (IPv4)	B3,B2 byte of the subnet mask	B1,B0 byte of the subnet mask	B3,B2 byte of the default gateway address	B1,B0 byte of the default gateway address	B5,B4 byte of the transducer MAC address	B3,B2 byte of the transducer MAC address	B1,B0 byte of the transducer MAC address
		acquired from DHCP or entered manually when DHCP is off, format: B3.B2.B1.B0						format : B5:B4:B3:B2:B1:B0		
Ethernet interface parameters	AddrMTC	PortMbus	TimeMbus	no.c.TCP	p.comFTP	port FTP	portHTTP	10/100Mb	EthStdPa	ReInitEt
	Device address for Modbus TCP/IP service	Modbus TCP/IP port	Port closing time of Modbus TCP/IP service port if idle [s]	The number of allowed simultaneous connections to Modbus TCP/IP service	FTP server data port	FTP server command port	Web server port number	Baud rate	Setting the new parameters of Ethernet interface	Executing the changes in the Ethernet interface parameters
Settings Service	Fabr.Par	Security	Time	Date	AutoTime	DispTest	Language	SaveFile	Separat.	
service parameters	Enter standard parameters.	Enter a password	Setting the current time	Setting the current date	Automatic DST and inversely	LCD display and LED indicators test	Menu language selection	Override allowing for saving the configuration file to SD/SDHC card	Decimal separator character in the file archive	


Fig. 8 Programming matrix




5.4.1. Type of selected parameter value change

To increase the value of selected parameter, press the following button: . Pressing the button once increases the value by 1. Increasing the value by one when 9 is displayed, changes this number to 0. Number is changed after the following button is pressed: . Pressing the button  during the most important number allows to change the number sign after the following button is pressed: .

To accept the set parameter, press the following button: . The parameter will be saved. Pressing the following button:  while changing the parameter value will cancel the writing.

5.4.2. Changing the floating-point values

The change is done in 3 stages (to move to a next stage press the following button: ).

- setting the decimal point (00000., 0000.0, 000.00, 00.000, 0.0000);
 button moves the point to the left, while  button moves point to the right. Pressing the following button:  while changing the parameter value will cancel the writing.
- setting the value from -99999...99999 ranges for the normal values;
- setting the order of magnitude $\times 1$, $\times 10^3$, $\times 10^6$, $\times 10^9$ (symbols „k”, „M” and „G” for orders of 10^3 , 10^6 , 10^9 respectively are displayed)

5.4.3. Programmable parameters of the transducer

The following table shows the programmable parameters and the range of their values.

Table 1

Settings Input			
Parameter symbol	Description	Range of changes	
VoltRang	Selection of range of voltage measurement	12 V	Input range 12 V
		48 V	Input range 48 V
		100 V	Input range 100 V
		250 V	Input range 250 V
DemandTm	Synchronization of voltage, current and average power	Mov. Wind	15-minute moving window, value not synchronized with the clock
		15 min	The measurement synchronized with the clock, the time aggregation 15 minutes
		30 min	The measurement

			synchronized with the clock, the time aggregation 30 minutes
		60 min	The measurement synchronized with the clock, the time aggregation 60 minutes
Averag.	Averaging time of instantaneous values	20ms	Averaging time 20 ms
		200 ms	Averaging time 200 ms
		500 ms	Averaging time 500 ms
		1 s	Averaging time 1 s
		3 s	Averaging time 3 s
		5 s	Averaging time 5 s
		10 s	Averaging time 10 s
I direct	Reverse the current direction in measuring circuit	Normal.	Acc. to connection diagramm
		Reversed	Inversely with connection diagramm
Clear En	Clear energy counter	No	No changes
		Consumed	Clear imported energy counter
		Produced	Clear exported energy counter
		Capacity	Clear capacity counter
		All	Clear all energy counters
Reset AV	Restart counting the average values	No	No changes
		Yes	restart
TempMeas	Switching on the temperature measurement	No	No temperature measurement
		RS-485	Value from register 8000
Rst. Coun	Timer reset	Yes	Timer reset
		No	No changes
CurrThrs	Current threshold above which time is counted	-99999G...99999G	
Syn. Time	Selection of timer	stop	Stop the timer

	synchronization	start	Timer start
		synch. I	Automatic timer start after the threshold of startup current CurrThrs is exceeded
DeltTime	Selecting the time to indicate the delta voltages and currents	5 s	The time interval in determining the delta voltages and currents – 5 s
		30 s	The time interval in determining the delta voltages and currents – 30 s
		1 min	The time interval in determining the delta voltages and currents – 1 min
		5 min	The time interval in determining the delta voltages and currents – 5 min
		15 min	The time interval in determining the delta voltages and currents – 15 min
CurrThrs	Current threshold above which time is counted	-99999G...99999G	
Primar.U	Input voltage (included when calculating the rescaling ratio)	0...99999G	
Second.U	Output voltage (included when calculating the rescaling ratio)	0...99999G	
Shunt I	Shunt nominal current	0...99999G	
Shunt mV	Voltage corresponding to the shunt nominal current [mV]	0...99999G	

Table 2

Settings Display		
Parameter symbol	Description	Range of changes
Bcklight	Time of a display panel illumination	On - permanently switched on Off - permanently switched off 1 - switched on for X seconds 2 ... 60
Bckl.Int	Intensity of LCD display panel illumination	10% - LCD display panel illumination, 10% of max. illumination 20% - LCD display panel illumination, 20% of max. illumination ... 100% - LCD display panel illumination, 100% of max. illumination
Disp.Reg	Register number displayed on the bottom line of the display	0...65535

Table 3

Settings Alarm 1, Alarm 2			
Parameter symbol	Description	Range of changes	
Param. A1 Param. A2	Input value type controlling the alarm	U	voltage
		I	current
		P	power
		dU	Delta of voltage in the time interval
		dI	Delta of current in the time interval
		t s	Timer in seconds
		t GG, MM	Timer in hours, minutes
		C Ah	Capacity
		PAV	Average power
		UAV	Average voltage

		IAV	Avarage current
		Temper.	temperature
		2nd Val	second value displayed
		Clock	time
Type A1 Type A2	Alarm type. Fig. 12 shows the rendering of the alarm types.	n-on	normal (change from 0 to 1).
		n-off	normal (change from 1 to 0).
		on	on
		off	off
		h_on	manual off; alarm output is permanently switched on until change of the alarm type.
		h_off	manual off; alarm output is permanently switched on until change of the alarm type.
OverLoA1 OverLoA2	Alarm lower limit	-999999G...999999G	
OverHiA1 OverHiA2	Alarm upper limit	-999999G...999999G	
DlyOnA1 DlyOnA2	Alarm activation delay (s)	0...9 00	
DlyOffA1 DlyOffA2	Alarm deactivation delay (s)	0...9 00	
OnLockA1 OnLockA2	Alarm re-activation delay (s)	0...9 00	
SgKeepA1 SgKeepA2	Alarm signalization latch after the alarm is off (alarm memory)	Off	no alarm signalization latch
		On	alarm signal support by the pulsating A1 and A2 LEDs after the alarm sound ends

Table 4

Settings Output			
Parameter symbol	Description	Range of changes	
Param. A1	Input value type controlling the analog output	U	voltage
		I	current
		P	power
		dU	Delta of voltage in the time interval
		dI	Delta of current in the time interval
		t s	Timer in seconds
		t GG, MM	Timer in hours, minutes
		C Ah	Capacity
		PAV	Avarage power
		UAV	Avarage voltage
		IAV	Avarage current
		Temper °	temperature
		2nd Val	second value displayed
		Clock	time
AnIn Lo1	Individual characteristic of analog output 1- lower limit of the input	-999999G . . . 999999G	
AnIn Hi1	Individual characteristic of analog output 1- upper limit of the input	-999999G . . . 999999G	
AnOutLo1	Individual characteristic of analog output 1- lower limit of the output	0 . . . 24.000	
AnOutHi1	Individual characteristic of analog output 1- upper limit of the output	0 . . . 24.000	
OverSer1	Enabling an overrun of the analog output 1	Off	Overrun support disabled
		On	Overrun support enabled

OvOutLo1	Lower limit overrun of output 1 (value x1000)	0 . . . 24000
OvOutHi1	Upper limit overrun of output 1 (value x1000)	0 . . . 24000
OvrOutL1	Output expected value when the lower limit is exceeded (value x1000)	0 . . . 24000
OvrOutH1	Output expected value when the upper limit is exceeded (value x1000)	0 . . . 24000
Param. A2 OvrOutH2	Parameters as for A1; available only for the transducers with additional no. 2 output	

Table 5


Settings Mbus 485			
Parameter symbol	Description	Range of changes	
Address	MODBUS network address. Entering the 0 value turns the interface off; if the RS-485 interface operates in the Master mode, it is an address of the queried device.	0 . . . 247	
ModeUnit	The transmission frame type of RS-485 interface	r8n2 r8e1 r8o1 r8n1	
BaudRate	RS-485 interface baud rate	4800	4800 bit/s
		9600	9600 bit/s
		19200	19200 bit/s
		38400	38400 bit/s
		57600	57600 bit/s

		115200	115200 bit/s
		230400	230400 bit/s
		256000	256000 bit/s
Base.Reg	Number of the base register queried/monitored in the Master or Monitor mode of RS-485 interface	0 ... 65536	
No.ofVal	Number of values queried in Master mode or monitored in Monitor mode	0 ... 50	
ValType	Type of the values queried/monitored by RS-485 interface	char 8	Register type <i>char</i> (8 bits signed)
		uchar 8	Register type <i>unsigned char</i> (8 bits unsigned)
		short 16	Register type <i>short</i> (16 bits signed)
		ushort16	Register type <i>unsigned short</i> (16 bits unsigned)
		long 32	Register type: <i>slong</i> (32 bits unsigned)
		ulong 32	Register type: <i>unsigned long</i> (32 bits unsigned)
		flt 32	Register type <i>char</i> (32 bits, signed variable comma)
		sf1t2x16	Register type: swapped <i>float</i> , value in two 16-bit registers (byte sequence: 3,2,1,0)
		flt 2x16	Register type: <i>float</i> , value in two 16-bit registers (byte sequence: 1,0,3,2)
		lng 2x16	Register type <i>long</i> , value in two 16-bit registers (32 bits signed, byte sequence

			1,0,3,2)
		s1ng2×16	Register type <i>swapped long</i> , value in two 16-bit registers (32 bits signed, byte sequence 3,2,1,0)
		u1ng2×16	Register type <i>unsigned long</i> , value in two 16-bit registers (32 bits unsigned, byte sequence 1,0,3,2)
		uS1n2×16	Register type <i>unsigned swapped long</i> , value in two 16-bit registers (32 bits unsigned, byte sequence 3,2,1,0)
Interv.	Query period for the device in Master mode	1...36000 [0.1 ... 3600 s]	
AnswTime	Maximum time before the response from the device queried by transducer with RS-485 interface operating in Master mode or Monitor mode	10...5000 [ms]	
Mode	Interface RS-485 operating mode	Slave	The transducer serves as Slave on the RS485 line, waiting for the queries and responds if they are addressed
		Monitor	The transducer monitors the traffic on the RS485 line and reacts to data exchange between the external devices working as Master and Slave
		Master	Transducer uses Master function on the RS-485 link, sends queries and analyzes responses received from the Slave device

Mast. Fun	Modbus protocol function used by the transducer working with RS-485 interface in Master mode	fun. 0x03	Function 0x03
		fun. 0x04	Function 0x04
No. Of Err	Maximum allowed number of repeated queries for the transducer with RS-485 interface in Master mode	0 . . . 10	

Table 6

Settings Archive			
Parameter symbol	Description	Range of changes	
Arch. Val	Selecting archived values Press again  to select the value (Each of the 16 measured values must be assigned „Yes” or „No” option, depending on whether the selected value should be archived or not) <u>Caution: change of register value will result in deletion of the internal memory archive!</u>	U	voltage
		I	current
		P	power
		dU	Delta of voltage in the time interval
		dI	Delta of current in the time interval
		t s	Timer in seconds
		t GG, MM	Timer in hours, minutes
		C Ah	Capacity
		PAV	Avarage power
		UAV	Avarage voltage
		IAV	Avarage current
		Temper.	temperature
		2nd Val	second value displayed
		Clock	Real Time Clock
Param. Ar	Input value type controlling the conditional archiving	U	voltage
		I	current
		P	power
		dU	Delta of voltage in the time interval

		dI	Delta of current in the time interval
		t _s	Timer in seconds
		t _{GG, MM}	Timer in hours, minutes
		C _{Ah}	Capacity
		PAV	Avarage power
		UAV	Avarage voltage
		IAV	Avarage current
		Temper.	temperature
		2nd Val	second value displayed
		Clock	time
Ar. Mode	Archiving engagement condition. Fig. 19 shows the types of archiving engagement conditions (as per the types of alarms).	n-on	normal (change from 0 to 1).
		n-off	normal (change from 1 to 0).
		on	on
		off	off
		h_on	manual off; alarm output is permanently switched on until change of the alarm type.
		h_off	manual off; alarm output is permanently switched on until change of the alarm type.
OverLoAr	Conditional archiving lower limit	-99999G...99999G	
OverHiAr	Conditional archiving upper limit	-99999G...99999G	
Ar. Time	Archiving period (s)	1...3600	
Ar. Erase	Deleting an internal archive	Yes	deleting an internal archive
		No	do nothing
Rec. ToSD	Forced rewriting of the archive contents from internal memory to external SD/SDHC card (type: P30H-	Yes	rewriting of the internal archive to the SD/SDHC card
		No	do nothing

	X1XXXXXX) or to file system internal memory (type: P30H-X2XXXXXX)		
Param. SD	The percentage of the internal archive space used which triggers automatic writing to SD/SDHC card	5 ... 95	

Table 7

Settings Ethernet (option, only type P30H-XX2XXXXXX)			
Parameter symbol	Description	Range of changes	
DHCP	Enabling/disabling the DHCP Client (supports automatic obtaining of IP protocol parameters of the transducer Ethernet interface from external DHCP servers in the same LAN)	Off	DHCP disabled - you should manually configure the IP address and subnet mask of the transducer;
		On	DHCP enabled, transducer will automatically receive the IP address, subnet mask, and gateway address from the DHCP server when switching power is turned or Zastozm option is selected from the menu; The gateway address is the address of the server that assigned the parameters to the transducer;
addrIP32	Third and second byte (B3.B2) of the transducer IP address, a value is displayed in decimal format, IPv4 address format: B3.B2.B1.B0	000.000 ... 255.255	
addrIP10	First and zero byte (B1.B0) of the transducer IP address, a value is displayed in	000.000 ... 255.255	

	decimal format, IPv4 address format: B3.B2.B1.B0	
mask 32	Third and second byte (B3.B2) of the transducer subnet mask, a value is displayed in decimal format, mask format: B3.B2.B1.B0	000.000 ... 255.255
mask 10	First and zero byte (B1.B0) of the transducer subnet mask, a value is displayed in decimal format, mask format: B3.B2.B1.B0	000.000 ... 255.255
Gate 32	Third and second byte (B3.B2) of the transducer default gateway, a value is displayed in decimal format, gateway address format: B3.B2.B1.B0	000.000 ... 255.255
Gate 10	First and zero byte (B1.B0) of the transducer default gateway, a value is displayed in decimal format, gateway address format: B3.B2.B1.B0	000.000 ... 255.255
MAC 54	Fifth byte and fourth (B5.B4) of the transducer MAC address, a value is displayed in decimal format; format B5:B4:B3:B2:B1:B0	000.000 ... 255.255
MAC 32	Third and second (B3.B2) of the transducer MAC address, a value is displayed in decimal format; format B5:B4:B3:B2:B1:B0	000.000 ... 255.255
MAC 10	First and zero byte (B1.B0) of the transducer MAC address, a value is displayed in decimal format; format B5:B4:B3:B2:B1:B0	000.000 ... 255.255
AddrnTCP	Device address for Modbus TCP/IP protocol	0 ... 255
PortMbus	Modbus TCP port number	0 ... 65535

TimeMbus	Port closing time of Modbus TCP/IP service, in seconds	10 ... 600	
no. c. TCP	The maximum simultaneous connections to Modbus TCP/IP service	1 ... 4	
p. komFTP	FTP server commands port number	20 ... 65535	
FTP port	FTP server data port number	20 ... 65535	
PortHTTP	Web server port number	80 ... 65535	
10/100Mb	Baud rate	Auto	automatic
		10 Mb/s	10 Mbit/s
		100 Mb/s	100 Mbit/s
EthStdPa	Setting the new parameters of Ethernet interface	Yes	Restoring the default parameters of Ethernet interface
		No	no change
ReInitEt	Saving the new parameters of the Ethernet interface	Yes	Saving the new parameters and initiate Ethernet interface
		No	no change

Table 8

Settings Support			
Parameter symbol	Description	Range of changes	
Fabr. Par	Entering default setting. Setting "yes" value resets transducer parameters to their default values. Values of default parameters are presented in Table 15.	No	do nothing
		Yes	sets default factory values.
Security	Entering new password. Entering 0 value turns password protection off.	-99999 ... 99999	
Time	Setting the current time. Entering invalid time value cancels time setting.	00:00 ... 23:59	

	Entered value will not be used.		
Date	Date setting - month+day. Entering invalid date value cancels date setting. Entered value will not be used.	01-01-10...31-12-99	
AutoCzas	Automatic DST and inversely	No	no automatic daylight saving time change
		Yes	with automatic daylight saving time change
TestWysw	LCD display and LED indicators test	No	do nothing
		Yes	starts the test
Language	Menu language selection	Polish	selection of Polish language
		English	selection of English language
SaveFile		No	do nothing
		Yes	Forced transducer configuration file saving to the external SD/SDHC card or file system internal memory
Separat.	Decimal point selection for archive files	.	dot
		,	comma

5.5. Functions of the transducer

5.5.1. Measuring input

The transducer measures the voltage and current values on the basis of which calculates other parameters such as - power, energy, capacity. Measuring signals of voltage and current are sampled at a frequency of 6,4 kHz.

5.5.1.1 Averaging time of instantaneous values







The default averaging time of instantaneous values is set to 1

second fir P30H transducer. This time can be changed to one of the predefined values: 0.02, 0.2, 0.5, 1, 3, 5, 10 seconds. Instantaneous values include: voltage, current (registers 7500...7507).

5.5.1.2 Mean values, synchronized with the clock

For the values of active power, apparent power and current (registers 7508..7510) an averaging function for the period of 15, 30 and 60 minutes is available average values are synchronized with the real time clock, so that the values change after every full quarter, 30 minutes or every hour. Synchronization with the stepped 15-minutes window not synchronized wit the real time clock is also available.

5.5.1.3 Maximum and minimum values displayed

P30H transducer uses a minimum and maximum value memory function for all displayed values (registers 7500... 7514). Minimum and maximum values can be read and deleted using the transducer registers via Modbus protocol (RS-485, TCP/IP – see Tab. 43) or WWW server, they can also be displayed for the current displayed value after pressing the following key sequence:   - maximum value,   - minimum value. Maximum and minimum values can be deleted via the keyboard by pressing the following key sequence:   . Maximum and minimum values are available in the register range 7532...7561.

5.5.1.4. Transducer configuration example for control of charging lead acid battery

Schematic below illustrates connection of P30H transducer used for control of charging process of lead acid battery with nominal voltage of 12V and capacity of 60Ah, with the use of the external DC voltage source.




Fig. 9 P30H connection schematics in configuration for control of battery charging

Assumed charging parameters:

- ◆loading time – ca. 24h

- ◆loading start condition – voltage level $\leq 9,0 \text{ V}$
- ◆loading end condition – voltage level $\geq 14,4 \text{ V}$
- ◆parameters of external DC supply - $16 \text{ V d.c.}, 150 \text{ W}$

If the 60Ah battery is discharged to, for example 9V level, it should be loaded with average current of $I_{av} = 2,5 \text{ A}$ ($2,5 \text{ A} * 24 \text{ h} = 60 \text{ Ah}$).

If loading is made through DC source, it is necessary to use the current limiting resistor. $R_{\text{current limiting}}$ with proper nominal power. The initial current can be established to have double value of average current:

$$I_{\text{initial}} = 2 * I_{av} = 5 \text{ A.}$$

Current limiting resistor $R_{\text{current limiting}}$ shall be choosen in such way, that initial current value would be 5A at the battery voltage of 9V. Nominal power of resistor must be sufficient.

$$R_{\text{current limiting}} = (14,4 \text{ V} - 9 \text{ V}) / 5 \text{ A} = 1.08 \Omega \approx 1 \Omega$$

Power losses on the resistor in first phase of loading are:

$$P_{\text{current limiting}} = U^2 / R_{\text{current limiting}} = (14,4 \text{ V} - 9 \text{ V})^2 / 1 \Omega = 29,16 \text{ W}$$

$$I_{\text{initial max}} = U / R = (14,4 \text{ V} - 9 \text{ V}) / 1 \Omega = 5,4 \text{ A}$$

Measuring shunt R_{shunt} should be chosen in such way, that it allows to fully utilize the shunt input measuring range - $U_{\text{shunt}} = 150 \text{ mV}$.

$$R_{\text{shunt}} = U_{\text{shunt}} / I_{\text{initial max}} = 0,15 \text{ V} / 5,4 \text{ A} = 0,0277 \Omega \approx 0,02 \Omega, \text{ - the shunt should be } 0,02 \Omega \text{ (or less)}$$

Configuration of P30H transducer:

The circuit will be controlled with the usage of alarm relay no. 1 (stopping the loading process when the 14,4V threshold is met)

Register no	Parameter symbol in Menu	Register value	Parameter symbol in Menu	Description
4000	VoltRang	0	12 V	Voltage measuring range
4001*	Rst. Coun	1	Yes	Timer reset

4003	Averag.	6	10 s	Averaging time of instantaneous values
4004	Syn.Time	2	Synch. I	Synchronization of timer with value of charging current
7619	CurrThrs	0,05	0,05	Current threshold above which time is counted
4005	I direct	0	Normal.	Normal direction of current
4008*	Clear En	4	4	Clearing all energy counters and capacity
4012	DeltTime		5 min	The interval for calculating difference of voltage and current(dU, dI)
4026	Param.A1	0	U	Alarm no 1 control with voltage value
4027	Type A1	1	n-off	Workin mode of Alarm 1
4028	DlyOnA1	0	0	Alarm 1 activation delay
4029	DlyOffA1	0	0	Alarm 1 activation delay
4030	OnLockA1	0	0	Alarm 1 reactivation delay
4031	SgKeepA1	1	1	Alarm 1 signalization latch
7600	OverLoA1	9,000 0	9,0000	Alarm 1 lower limit
7601	OverHiA1	14,40 0	14,400	Alarm 1 upper limit
7621	Primar.U	1,000 0	1,0000	Rescaling ratio for voltage measuring input value is 1
7622	Second.U	1,000 0	1,0000	
7623	Shunt I	5,000 0	5,0000	Rescaling ratio for current measuring


7624	Shunt mV	100,0 0	100,00	input value for: $R_{\text{shunt}} = 0,02 \Omega$, $I = 5A$ $U_{\text{shunt}} = 100 \text{ mV}$ rescaling ratio is therefore $5A/0,1V = 50 \text{ A/V}$
* - after saving the parameter the register value will automatically set to "0"				

5.5.2. Analog outputs

P30H transducer is always equipped with one main analog output (output #1) for current (source) or voltage, depending on the version. Output is connected to the terminals 15 and 16. Depending on the version, transducer can be equipped with an additional analog output (output #2) in place of the alarm output using the terminals 13-14.

5.5.2.1. Individual characteristic of analog outputs

T30P transducer allows for processing measured values that are converted to output signal based on the analog output linear characteristics. On the base of given coordinates of two points by the user, the transducer determines (from the system of equations) coefficients a and b of the individual characteristic.



where $X1\ in$ and $X2\ in$ – displayed value, $Y1\ out$ and $Y2\ out$ – expected value on analog output.

Fig.10 Individual characteristic of analog output

5.5.2.2 Analog outputs overrun support

P30H transducer allows the user to configure the analog outputs to handle the overrun of the defined threshold values. Overrun support is disabled by default – in such case, after the value controlling the output is overrun, the output is still controlled proportionally to the controlling value outside the basic output range. After the overrun support is enabled, user can define the output controlling value in case of the maximum or minimum output value overrun.

Example: Main analog output 1 configuration

Output set to react to the value of averaged power. Individual characteristics of the current analog output is set as follows:

Table 9

Register no.	Parameter symbol in the menu	Register value	Parameter value symbol in the menu
4100	ParamAn1	8	PAV
4101	OverSer1	0	Off
7606	AnIn Lo1	-200	-200.0
7607	AnIn Hi1	1200	1200.0
7608	AnOutLo1	4000*	4000*
7609	AnOutHi1	20000*	20000*

* value in the register is an integer value multiplied by 1000 (4mA → value 4000)

The Fig. 10 presents the reaction of the analog output when the analog output overrun support is off – analog output standard operating mode.




Fig.11 Analog output with overrun support off

If the overrun support is turned on with all remaining values unchanged (parameters set according to Tab. 10), then the analog output will react as shown in the Fig. 11.

Table 10

Register no.	Parameter symbol in the menu	Register value	Parameter value symbol in the menu
4100	ParamAn1	8	PAV
4101	OverSer1	1	On
7606	AnIn Lo1	-200	-200.0
7607	AnIn Hi1	1200	1200.0
7608	AnOutLo1	4000*	4000*
7609	AnOutHi1	20000*	20000*
4102	OvOutLo1	0	0
4103	OvOutHi1	1000	1000
4104	OvrOutL1	1500*	1500*
4105	OvrOutH1	3500*	3500*

* value in the register is an integer value multiplied by 1000 (4mA → value 4000)




Fig. 12 Analog output with threshold limit handling on

Example: Main analog output (no. 1) configuration for the time reaction

Individual characteristics of the analog output no. 1 (current) are set so that the output reacts to the real time (hour*100+minute), i.e. for the 00:00 hours, the expected value is 4 mA and for 23:59 hours, the expected value is equal to 20 mA:

Table 11

Register no.	Parameter symbol in the menu	Register value	Parameter value symbol in the menu
4100	ParamAn1	16	Clock
4101	OverSer1	0	Off
7606	AnIn Lo1	0	0.0
7607	AnIn Hi1	23.59	23.59
7608	AnOutLo1	4	4
7609	AnOutHi1	20	20.0

If the transducer is equipped with additional analog output (no. 2), it should be configured in the same way as main output, using the transducer → parameter menu: ParamAn2 ...OvrOutH2 or with registers (according to their description in Tab. 37).

Caution!

If the transducer is not equipped in additional analog outputs, then relevant parameters are not available. If the analog output has the threshold handling turned on, then configuration parameters for threshold handling are not available in the menu.

5.5.3 Alarm and power outputs

P30H transducer can be equipped with 2 normally open alarm contacts or 1 output with normally open contact and 1 24 VDC power output. (depending on version) Each alarm (24 VDC power output should be treated like one) can operate in one of six available modes. The Fig. 12 presents alarm operating in the following modes: n-on, n-off, on, off. Other two modes: h-on and h-off stand for always on and always off, respectively. These modes are used for manual simulation of the alarm state.

In case of the transducer version fitted with 24 VDC power output, second alarm should set as h-on, the auxiliary power output will be always on.




Fig. 13 Alarm types: a) n-on; b) n-off; c) on; d) off.

AL_L - Alarm lower limit

AL_H – Alarm upper limit

Caution: In case of alarm type *n-on*, *n-off*, *on*, *off* entering the $AL_L > AL_H$ value will disable the alarm.

5.5.4 LCD display












P30H transducer is equipped with illuminated LCD display with two lines, 8 characters each. Upper display line is used to show values displayed in float format (5 digits for the value < 1000.0 or 4 digits + magnitude symbol for values ≥ 1000.0) and to display status icons of the SD/SDHC card, or after pressing the key sequence   or   to display icons of the minimum and maximum value of the displayed parameter. Displayed values belong to the range of -9999G...9999G.



Table 12



Symbol	Display mode	Meaning
	continuous	SD/SDHC card or file system internal memory mounted and ready
	flashing	SD/SDHC card unmounted and ready to remove
	flashing	SD/SDHC card write-protected
	flashing	SD/SDHC card or file system internal memory is full
	continuous	Displaying maximum value
	continuous	Displaying minimum value

P30H transducer automatically sets the format (precision) of the display to the displayed value.

Measurement range overrun is signaled by special signs displayed in the upper line of the LCD.

-  – overrun of the lower range limit for the value displayed
-  – overrun of the upper range limit for the value displayed

Lower line of the P30H transducer display can perform several functions. Pressing the following button:  or  cycles the functions of the lower display line:

- name of the displayed value complete with the unit and the internal memory fill indicator. ()
- time in HH:MM:SS
- date in DD:MM:YY
- bar graph showing the percentage control of the analog output
- second displayed value  - value of any transducer register projected onto the float number – number of the register to be displayed should be entered into the register 4024 (to display the float value contained in 16-bit registers, e.g. register 7000, a relevant 32-bit register number should be entered, in this case - > 7500.)




Fig. 14 Graph showing the cycling of the lower display line information.










Fig. 15 Graph showing displayed information when buttons are used for cycling. And .

Table 13

Symbol	Description
U V	Voltage
I A	Current
P W	Power
dU V	Delta of voltage in the time interval – difference between tvalues of voltage values at the end and at the beginning of the set time interval
dI A	Delta of current in the time interval– difference between tvalues of voltage values at the end and at the beginning of the set time interval

t s	Timer in seconds
t H, M	Timer in hours, minutes
C Ah	Capacity
PAV W	Average power
UAV V	Average voltage
IAV I	Average current
T °C	Temperature (option)
E_{\leftarrow} Wh	Imported energy
E_{\rightarrow} Wh	Exported energy
E_{Σ} Wh	Sum of energy (imported and exported)
E_{Δ} Wh	Difference of energy (imported and exported)

After the power is turned on, the first value displayed is by default the voltage shown in the upper display line, while the lower line shows symbol and unit of the displayed value.

Displayed values are cycled by following buttons:  and  According to the diagram shown in Fig. 14. For every displayed value it is possible to show minimum and maximum values using the following buttons:   and  .

LCD can also show service and maintenance information showing the transducer status – see Tab. 14

Table 14

Message	Description
Restore Fabr. Par	Default value setting message, e.g. after the software update, transducer can operate normally – it is necessary to revert to factory settings; the message does not interfere with the display of the measured values – it is cycled.
Fabr. Par done	Successful reset to factory settings message, the message does not interfere with the display of the measured values – it is cycled every 20 seconds.

5.5.5 Saving and reading transducer configuration file

P30H transducer in P30H-X1XXXXXX and P30H-X2XXXXXX version allow for reading and writing the configuration file from the external SD/SDHC card or file system internal memory.


5.5.5.1 Saving transducer configuration file


Writing of the current configuration file is possible after selecting a `Service → SaveFile → Yes` option from the menu or after entering value “1” into register 4078. Configuration text file will be saved in the **P30H** folder, filename: **P30H_PAR.CON** (point 5.8.4, Fig. 19). Subsequent configuration file write command will overwrite previously created file.

5.5.5.2 Reading transducer configuration file

Loading the transducer configuration from the file allows for quick configuration of the transducer equipped with the external SD/SDHC card or file system internal memory. Configuration file should be located in the **P30H** folder and be named **P30H_PAR.CON**. File can be generated by properly configured P30H transducer or by the eCon

software used to configure P30H transducers (ModBus RS-485 or TCP/IP). For P30H transducers in P30H-X2XXXXXX version, file can be transferred between devices via FTP. For P30H transducers in P30H-X1XXXXXX version, single file on a memory card can be used to configure several transducers equipped with SD card slot.


To force parameter update from the file, power the transducer on while holding the following button:  . If the file contains correct data and the configuration is accepted, the display will show following message:



Par. from
file Set

Fig. 16 Message after successful loading of the configuration file.

If the parameter update was forced but no file was present or the file contains invalid data (at least one invalid parameter), the current configuration is not overwritten and the following message appears on the display:



Error File

Fig. 17 Message after unsuccessful loading of the configuration file

5.6. Default settings

Table 15 shows the standard settings of the P30D transducer. These settings can be reverted via the following option in the transducer menu: `Settings Service → Fabr.Par → Yes` or via the RS-485 interface after entering value “1” into register 4055.

Table 15

	Parameter symbol	Standard value
Input	VoltRang	12 V
	DemandTm	Mov. Wind
	Averag.	1s
	I direct	Normal
	Clear En	No
	Reset AV	No
	TempMeas	No
	Rst. Coun	No
	Syn. Time	stop
	DeltTime	5s
	CurrThrs	0,0000
	Primar. U	1,0000
	Second. U	1,0000
	Shunt I	150,00
	Shunt mV	150,00
Display	Bcklight	On
	Bckl. Int	70,00%
	Disp. Reg	7509
Alarm 1,2	Param. A1 Param. A2	U
	Type A1 Type A2	h-off
	OverLoA1 OverLoA2	0
	OverHiA2 OverHiA2	0
	DlyOnA1 DlyOnA2	0

	DlyOffA1	DlyOffA2	0
	OnLockA1	OnLockA2	0
	SgKeepA1	SgKeepA2	On
Output	Param.A1	Param.A2	C Ah
	AnIn Lo1	AnIn Lo2	40
	AnIn Hi1	AnIn Hi2	60
	AnOutLo1	AnOutLo2	4
	AnOutHi1	AnOutHi2	20
	OverSer1	OverSer2	Off
	OvOutLo1	OvOutLo2	4000
	OvOutHi1	OvOutHi2	20000
	OvrOutL1	OvrOutL2	4000
	OvrOutH1	OvrOutH2	20000
Mbus 485	Address		1
	ModeUnit		r8n2
	BaudRate		9600
	Base.Reg		7510
	No.ofVal		1
	ValType		f1t 32
	Interv.		10
	AnswTime		1000
	Mode		Slave
	Mast.Fun		0x03
	No.OfErr		2
Archive	Arch.Val		U, I, P, Q, S
	Param.Ar		U
	Ar. Mode		h_off
	OverLoAr		0
	OverHiAr		20
	Ar. Time		10
	Ar.Erase		No
	Rec.ToSD		No
	Param.SD		1.05.2000
	Fabr.Par		No
	Security		00000
	Time		Undefined

Service	Date	Undefined
	AutoTime	No
	DispTest	No
	Language	Polish (for versions P30H-XXXXXXXXPX English (for versions P30H-XXXXXXXXEX)
	SaveFile	No
	Separat.	, (for versions P30H-XXXXXXXXPX) ▪ (for versions P30H-XXXXXXXXEX)
Ethernet (optional)	DHCP	On
	addrIP32	192.168
	addrIP10	001.030
	mask 32	255.255
	mask 10	255.000
	Gate 32	192.168
	Gate 10	001.001
	MAC 54	Variable value - individual for each transducer
	MAC 32	
	MAC 10	
	AddrnTCP	1
	PortMbus	502
	TimeMbus	60
	no. c. TCP	4
	p. comFTP	21
	FTP port	1025
	PortHTTP	80
	10/100Mb	Auto
	EthStdPa	No
	ReInitEt	No

5.7. Software upgrades

A feature implemented in the P30H transducers enables to upgrade firmware using a PC with eCon software installed. Free eCon software and the update files are available at www.lumel.com.pl. Upgrade is possible if a PC is connected to RS485 to USB converter, such as PD10 converter.






Fig.18 View of the program for updating transducer software.

Caution! Software update automatically resets transducer settings to default, so it is recommended to save the settings using eCon software before upgrading.



After starting the eCon software, go to the **Communication** tab and set baud rate, mode, transducer address and RS-485 interface port. Then click the **Connect** icon and read all set parameters (it is

necessary to revert them later). Next, click the **Firmware update** link, the LUMEL UPDATER (LU) software will appear – Fig. 24. Press the **Connect** button. The **Messages** information window displays information concerning upgrade process. If the port is opened correctly, a **Port opened** message appears. Upgrade mode is enabled using either of the two methods: remotely via LU (using eCon settings: address, mode, baud rate, COM port) and by turning a transducer on while pressing the following button:  - update with standard communication parameters, i.e.: baud rate: 9600 kb/s, mode: 8N2 or with the following button pressed:  - update with recommended communication parameters, i.e.: baud rate: 115200 kb/s, mode: 8N2. When all LEDs are lit and the „Connect UPDATER” message is displayed in the upper display line, the transducer is ready for the communication with PC. When transducer successfully connects to the LUMEL UPDATER software, LU program displays the following message: **Device found: P30H** , main program version and connected device bootloader version, while the transducer display shows the "Device is ready" message. Next, press the following button: ... ” to load the file with new software version in LUMEL UPDATER software. If the file is opened correctly, a **File opened** message is displayed in LU program window. Press the **Send** button. During update, signal LEDs are being lit in sequence, and the lower display line shows the percentage progress of the update. When upgrade is successfully completed, the transducer starts normal operation while the information window displays **Done** message and upgrade elapsed time.

Current software version can be checked by reading the welcome message when switching the transducer on.

Note: Software update is possible only when transducer is connected to PC (no other **Master** devices present on RS-485).



Caution: Turning the transducer power supply off during upgrade process may result in permanent damage!



5.8. Measuring values archiving

5.8.1 Transducer memory structure

P30 transducers are by default (regardless of the version) are equipped with 4MB internal memory to store data registered by the transducer. Any displayed value (registers 7500...7515) can be a registered parameter with an exception of meter values (energy meters). Second displayed value can be registered optionally. Internal memory of the transducer can store up to 534336 records. Memory is organized as a circular buffer. After the memory is full, the oldest data are overwritten first. Internal archive can be read, copied and deleted.

Additionally, P30H-XX1XXXXXXX version is equipped with SD/SDHC card slot, allowing the archive data as files on the external SD/SDHC card.

P30H-XX2XXXXXXX version is equipped with 8GB internal file system memory (memory size can be increased by manufacturer or on special order) storing the data automatically rewritten from the internal

memory. The files can be downloaded via Ethernet using FTP.

Caution: Changing the menu parameter value `Archive` → `Arch.Val` will result in erasing the internal memory archive!!!



5.8.2 Internal memory

Transducer internal memory is divided into 8192 pages. Every memory page can accommodate up to 66 data records. Records within one page begin from the beginning of the page and fill the entire page space. Every memory page is 528 bytes long. Memory is divided into two areas: first 8096 pages are the basic archive memory, while the remaining 96 pages are the reserve archive that is used only during rewriting memory contents to the SD/SDHC card (total memory is $8096 \times 528\text{B} + 96 \times 528\text{B} = 4275312$ bytes).









The starting point of the archived data is marked by the number of the page containing the first archive record and the starting byte determining page byte the first record starts from. The ending point of the archive is likewise marked by the number of the page containing the last archive record on that page and the first byte of the subsequent archive record to be written.

Deletion of the internal archive memory contents is done by assigning the archive end parameters to the archive start. This allows to retrieve memory contents in case archive is deleted.

Data in the internal archive memory are stored as 8-byte records. Current memory fill status can be displayed on LCD after setting the lower display line to show the unit and internal memory fill

indicator. Table 16 describes the internal memory fill indicator.

Table 16

Symbol								
Internal memory fill percentage	87.5...100%	75...87.5%	62.5...75%	50...62.5%	37.5...50%	25...37.5%	12.5...25%	0...12.5%

5.8.2.1 Structure of the record

All data written to the internal data memory are stored as 8-byte records. Structure of the record is presented in the table below.

Table 17

Internal memory record (8 bytes)					
Registration time (4 bytes)			Data archived in the float format (4 bytes)		
Year - 2010	Month	Day	Hour	Minute	Second
6 bits	4 bits	5 bits	5 bits	6 bits	6 bits

Example: Example of internal memory record coding – e.g. record no. 13 on page no. 559

Record no. 13 (rec=13) on 559 page is read from registers 4553 – 4556 (unsigned short type registers – 2 bytes, 1 record covers 4 unsigned short type registers) after entering the value 559 into the register 4500. Starting register holding the record starting point can be found according to the following formula: $R_0 = 4501 + rec * 4 = 4553$.

Table 18

Register	HEX value
4553	0x0170
4554	0xBB95
4555	0xE87C
4556	0xB942

rec = 0x0170BB95E87CB942

Data = 0xE87CB942 → (float) → 92.743958;

Table 19


Registration time = 0x0170BB95 → b1011100001011101110010101					
Year + 2010	Month	Day	Hour	Minute	Second
6 bits	4 bits	5 bits	5 bits	6 bits	6 bits
0 0 0 0 0 0	0 1 0 1	1 1 0 0 0	0 0 1 0 1 1	1 0 1 1 1 0	0 1 0 1 0 1
0 + 2010	5	24	11	46	21
10-05-24 11:46					



Rec : 2010-05-24 11:46:21 92.743958

5.8.2.2. Acquisition of archived data from the internal memory

Archived data in the internal memory can be downloaded by a memory card (optional), internal FTP server (optional) or RS-485 interface. Archived data acquisition is done by downloading memory pages containing data records. Downloading separate pages is possible thanks to eCon software.

Transducers equipped with SD/SDHC card slot allow for automatic rewriting of archived data to the memory card (the fastest way of archived data acquisition). To download the data using the card,

insert the SD/SDHC card into the slot (contacts side down), making sure that the card was successfully mounted (a following card icon is displayed in the upper left corner of the display: ). It is necessary to set the percentage fill threshold, because after this value is reached, the data will be automatically saved to card of file system internal memory – register 7614 or from menu: **Archive** → **Param. SD**. For example, if the value '20.0' is entered into the register 7614, data will be stored in the internal device memory until it is filled in 20%, when the device starts to write all subsequently saved data to SD/SDHC card or to file system internal memory. If the maximum percentage fill value is higher (e.g. 95%), data will be written to SD/SDHC card less often, but the saving process will be longer. Saving data to the card is marked by the progress bar on the lower LCD line. Do not remove SD/SDHC card from the device until the saving is completed, as this may cause data corruption or reset the device. Saving can be interrupted and the card removed after the card is unmounted, (see section 5.3.2).

It is also possible to force the rewriting of the archive to SD/SDHC card or to file system internal memory (only versions with Ethernet interface) after pressing the following key sequence:  . For the transducer with the Ethernet interface, archived data can be loaded from the file system memory via FTP with any FTP client.

Note: If the transducer is connected to FTP client, the ability to write archived data from internal memory to the file system internal memory is not available! To download current data from the archive, you have to disconnect from the FTP session, force the archive rewriting (e.g. via

following the combination of buttons:   and connect the transducer to FTP client again.

5.8.3 Archiving configuration

Archiving parameters can be configured via the registers 4064 – 4069 (Tab. 37) and transducer menu in the Settings → Archive group. Archiving can be continuous or conditional. Conditional archiving can be realized in one of four conditions presented on Fig. 19 (n-on, n-off, off, on). Continuous archiving can be enabled by selecting the 'h-on' option and disabled by selecting 'h-off'.




Fig. 19 Conditional archiving types

Ar_L - Archiving lower limit → OverLoAr → Register 7608

Ar_H - Archiving upper limit → OverHiAr → Register 7609

Example 1: Transducer configured for monitoring voltage, current, active power, THD U, THD I. Conditional archiving of five displayed values triggered by active power coefficient level – if PF falls below 0,9, transducer archives the values displayed every 10 seconds:

Table 20

Figure description	Register no.	Parameter symbol in the menu	Register value	Parameter value symbol in the menu
	4064	Arch.Val	7	U, I, P
	4065	Param.Ar	2	P
	4066	Ar. Mode	1	n-off
Ar_L	7608	OverLoAr	10	0.9
Ar_H	7609	OverHiAr	10	0.9
	4067	Ar. Time	10	10
	4068	Ar.Erase	0	No
	4069	Rec.ToSD	0	No
	7614	Param.SD	10	95.0

5.8.4 Memory card or internal memory file system (optional)

Transducers P30 in P30H-XX1XXXXXXXXX versions use memory card compatible with SD and SDHC standard. Transducers P30 in P30H-XX2XXXXXXXXX versions are equipped with file system internal memory – memory size 8GB. It is compatible with both FAT and FA32 file systems. If the memory card is not formatted, it should be formatted in the card reader from the PC level. P30H transducer creates directories and files containing archive data. Before the card is inserted in the transducer, make sure that the card is not write-protected. Never attempt to remove the card from the transducer before the card is



unmounted (see sec. 5.3.2) – the card is unmounted by pressing the buttons  . Removal of the card that was not unmounted may corrupt the card contents. Memory card status is described in the transducer registers (sec. 5.9.8. Tab. 42). After the card is inserted into the slot, the displays shows card status for about 3 seconds, as presented in the table below:

Table 21

Message	Description
Eject SD	The card inserted but not installed (uninstalled).
DamageSD	Card inserted but the attempt failed.
UnlockSD	The card inserted, installed correctly but write-protected. The card is uninstalled automatically when write-protection is detected.
SD OK or SDHC OK	The card inserted and installed.
Full SD	The card inserted and installed but full.
Install.	Card inserted – installation in progress

For example, number of records on the SD/SDHC card with archiving period of 1 second and for one archived value equals:

- 64 MB card: approx. 1.900.000 records (approx. 22 days)
- 2 GB card: approx. 60.800.000 records (approx. 700 days)

Caution: It is recommended to use industrial-grade SD/SDHC cards, with minimum 6th write class. It is also possible to use a consumer-grade cards compatible with the w 6th writing speed class (it should be remembered that consumer-grade cards can operate in the temperature range of 0...40°C).



P30H transducer creates directories and files on the card during registration. An example of the directory structure is shown in Figure 20.




Fig. 20 The directory structure on the SD card.

Besides the ARCH directory, holding the archived data, a SYSTEM directory is created on the card and complete with the file start.txt holding the date and hour of the installation of card or file system internal memory (also after the transducer is started after power failure).

Data on the card are stored in the files within directories corresponding to the name and serial number of the device – see Fig. 20. File names correspond to the registration date and follow the XXXX_YY.Dzz format, where XXXX → year, YY → month. Archive files extension is given in Dzz format, where „zz” is the following number of the archive file in given month. For example, first archive file in May 2015 will be named 2015_05.D00, the next file will be named 2015_05.D01 etc. For every month a maximum of 32 files can be created (*.D00 ... *.D31). File is automatically changed to another after it reaches the size of 12 MB when 1 or 2 values are archived. When more than 2 values are archived, the upper file size limit is set by the transducer.

5.8.5 Archive files structure

Archive data files on external SD/SDHC card or in file system internal memory are organized by columns separated by tab. A column description is located in the first line of the file. Data records are located in the subsequent lines and the record fields are separated by tab. An example of the file is shown in Fig. 21



date	time	U	I	P	Q	S
2015-01-08	11:53:52	2,299873e+02	4,050831e+00	4,655895e+02	8,069565e+02	9,316396e+02
2015-01-08	11:53:53	2,298834e+02	4,050681e+00	4,654074e+02	8,065356e+02	9,311841e+02
2015-01-08	11:53:54	2,298931e+02	4,050143e+00	4,653108e+02	8,064941e+02	9,310999e+02
2015-01-08	11:53:55	2,29946e+02	4,050473e+00	4,65361e+02	8,068003e+02	9,313901e+02
2015-01-08	11:53:56	2,299138e+02	4,050433e+00	4,653495e+02	8,066456e+02	9,312503e+02
2015-01-08	11:53:57	2,29978e+02	4,050689e+00	4,656675e+02	8,068306e+02	9,315696e+02
2015-01-08	11:53:58	2,299562e+02	4,050519e+00	4,653526e+02	8,068648e+02	9,314417e+02
2015-01-08	11:53:59	2,299042e+02	4,050245e+00	4,653154e+02	8,065707e+02	9,311686e+02
2015-01-08	11:54:00	2,299461e+02	4,050378e+00	4,655309e+02	8,066775e+02	9,313686e+02
2015-01-08	11:54:01	2,299325e+02	4,049969e+00	4,653634e+02	8,066018e+02	9,312195e+02
2015-01-08	11:54:02	2,299652e+02	4,050442e+00	4,6552e+02	8,067899e+02	9,314607e+02
2015-01-08	11:54:03	2,299246e+02	4,050336e+00	4,654569e+02	8,066081e+02	9,312717e+02
2015-01-08	11:54:04	2,298629e+02	4,050413e+00	4,654388e+02	8,063505e+02	9,310395e+02

Fig. 21 Example archive data file

Fields in the record line have the following meanings:

- **date** – date of data recording, separated by dash (-)
- **time** – hour, minute, second of recorded data, separated by colon (:)
- **U, I, P...** – archived values displayed by the transducer, separated by period (.) what can be changed. to comma (,) by selecting appropriate option in Service menu or entering value “1” into register 4070; archived values are written in the engineering format

5.9. RS-485 interface

Programmable digital P30H transducers are equipped with serial RS-485 link for communication with computer systems and other Master devices. Asynchronous character MODBUS communication protocol has been implemented in a serial link. The transmission

protocol describes how to exchange information between devices via a serial link.

5.9.1 Connection of the serial interface

RS-485 standard allows for a direct connection of up to 32 devices on a single serial link with a length up to 1200 m (at baud rate 9600 b/s). It is necessary to use additional intermediate-separation circuits for connecting higher number of the devices, for example PD51 manufactured by LUMEL S.A.

Output of the interface line is shown in Fig. 3. To obtain the correct transmission it is necessary to connect the lines A and B in parallel with their equivalents in other devices. The connection must use a shielded wire. The cable shield should be connected to the protective terminal in close proximity to the transmitter (connect a shield to the protective terminal at one point only).

GND line serves as the additional security device in case of significant connection line length. In such case, GND signals of all RS-485 bus devices should be interconnected.

RS-485 interface card or the converter is required for a connection to a PC, for example PD51 or PD10. The method of connecting devices is shown in Fig. 22.




Fig.22 Connecting the RS-485 interface.

Transmission line markings for the PC cards may vary depending on the card manufacturer.

5.9.2 Description of the MODBUS protocol implementation

The implemented protocol is compliant with the PI-MBUS-300 Rev G specification of Modicon.

Overview of P30H transducer MODBUS protocol serial port parameters:

- Transducer address 1..247.
- Baud rate: 4800, 9600, 19200, 38400, 57600, 115200, 230400, 256000 [b/s].
- Operating mode: RTU frame format: 8n2, 8e1, 8o1, 8n1.
- Maximum response time: 200 ms (time until the response start can be

extended up to 500ms during writing to a SD/SDHC card or to the file system internal memory).

Configuration of the serial link parameters consists of determining the baud rate, the device address and the format of the transmission mode - protocol.

Note: Each transmitter connected to the communication network must:

- have a unique address, different from the addresses of other devices connected to the network.
- Identical baud rate and a type of transmission mode

5.9.3 Description of the implemented functions

The following functions of the MODBUS protocol have been implemented in P30H transducers:

- 03 (03h) – readout of registers group
- 04 (04h) – readout of input registers group
- 06 (06h) – single register writing
- 16 (10h) – registers group writing
- 17 (11h) – slave device identification

Readout of n-registers (code 03h)

Example 1: Readout of 2 registers, starting with the register address 1DB0h (7600) float (32-bit), (register values 10, 100.)

Request:

Table 22

Device address	Function	Register address		Number of registers		CRC checksum
		B1	B0	B1	B0	
01h	03h	1Dh	B0h	00h	02h	C380h

Response:

Table 23

Device address	Function	Number of bytes	Value from the register 1DB0 (7600)				Value from the register 1DB1 (7601)				CRC checksum
			B3	B2	B1	B0	B3	B2	B1	B0	
01h	03h	08h	41h	20h	00h	00h	42h	C8h	00h	00h	E46Fh

Example 2: Readout of two 32-bit float registers (7501, 7502) as a combination of 2 x 2 16-bit registers (7002, 7003, 7004, 7005), starting with the register address 1B5Ah (7002) - 32-bit register values 25.68, 20.25.

Request:

Table 24

Device address	Function	Register address		Number of registers		CRC checksum
		B1	B0	B1	B0	
01h	03h	1Bh	5Ah	00h	04h	62FEh

Response:

Table 25

Device address	Function	Number of bytes	Value from the register 1B5A h (7002)		Value from the register 1B5Bh (7003)		Value from the register 1B5Ch (7004)		Value from the register 1B5Dh (7005)		CRC checksum
			Value from the register 7501 (32 bits)				Value from the register 7502 (32 bits)				
			B3	B2	B1	B0	B3	B2	B1	B0	
01h	03h	08h	41h	CDh	70h	A4h	41h	A2h	00h	00h	83D0h

Example 3: Readout of two 32-bit float registers (7501, 7502) as a combination of 2 x 2 16-bit registers (6002, 6003, 6004, 6005), starting with the register address 1772h (6002) - 32-bit register values 25.68, 20.25.

Request:

Table 26

Device address	Function	Register address		Number of registers		CRC checksum
		B1	B0	B1	B0	
01h	03h	17h	72h	00h	04h	E1A6h

Response:

Table 27

Device address	Function	Number of bytes	Value from the register 1772h (6002)		Value from the register 1773h (6003)		Value from the register 1774h (6004)		Value from the register 1775h (6005)		CRC checksum
			Value from the register 7501 (32 bits)				Value from the register 7502 (32 bits)				
			B1	B0	B3	B2	B1	B0	B3	B2	
01h	03h	08h	70h	A4h	41h	CDh	00h	00h	41h	A2h	E411h

Single register writing (code 06h)

Example 4: Writing the value 543 (0x021F) to the register 4001 (0x0FA1)

Request:

Table 28

Device address	Function	Register address		Register value		CRC checksum
		B1	B0	B1	B0	
01h	06h	0Fh	A1h	02h	1Fh	9B94h

Response:

Table 29

Device address	Function	Register address		Register value		CRC checksum
		Hi	Lo	Hi	Lo	
01h	06h	0Fh	A1h	02h	1Fh	9B94h

Writing to n-registers (code 10h)

Example 5: Writing two registers starting with the register address 1DB0h (7600)

Writing the values 20, 200.

Request:

Table 30

Device address	Function	Address reg.Hi	Address reg.Lo	No. of registers Hi	No. of registers Lo	Number of bytes	Value for the register 1DB0 (7600)				Value for the register 1DB1 (7601)				CRC checksum
							B1	B0	B3	B2	B1	B0	B3	B2	
01h	10h	1Dh	B0h	00h	02h	08h	41h	A0h	00h	00h	43h	48h	00h	00h	C9E2h

Response:

Table 31

Device address	Function	Register address		Number of registers		CRC checksum
		B1	B0	B1	B0	
01h	10h	1Dh	B0h	00h	02h	4643h

Device identification report (code 11h)

Example 6: Device identification

Request:

Table 32

Device address	Function	Checksum
01h	11h	C02Ch

Response:

Table 33

Address	Function	Number of bytes	Device ID	Device status	Field dependent on device		Checksum (CRC)
					Firmware v 2.00	Registers 4308, 4309, 4310, 4311 describing serial number, and device configuration of the transducer (ser. no.: 13100001)	
01h	11h	0Ch	C1h	FFh	02h 00h	A0h 01h 6Ch 0Dh A0h 01h 6Ch 0Dh	69FCh

Field dependent on the device – 4 bytes corresponding to the value of the registers 4308...4311, see Tab. 42. Production status 1...4.

5.9.4 Interface RS-485 Master mode

RS-485 interface can operate in Master mode, when the device can query single connected slave device. Both devices need to share communication parameters. Master mode is enabled by selecting the appropriate RS-485 operation mode from the menu: `Mbus 485` → `Mode` → `Master` or entering value "2" to register 4042. In Master mode, following parameters have to be configured in `Mbus 485` menu:

Table 34

Item	Mbus 485	
1	Address	Queried device address
2	ModeUnit	Transmission mode of a link
3	BaudRate	Baud rate
4	Base.Reg	Base register number
5	No.ofVal	Number of values queried
6	ValType	Type of values queried
7	Interv.	Query time [x100 ms]
8	AnswTime	Maximum response time [ms]
9	Mode	Serial interface operating mode

10	Mast.Fun	Function selection for Master mode (0x03 or 0x04)
11	No.OfErr	Number of query retries when no response is received

Parameters 4 - 6 can also be configured via RS-485 (registers 4048-4052) before *Master* mode is selected. After the *Master* mode is selected, transducer cannot be queried by another *Master* device.

All values read in *Master* mode are projected onto the float values and stored in registers 8000...8049, where first value read is put in the register 8000, second one is put in register 8001 etc.

In *Mbus 485* menu you can find the *No.OfErr* parameter, defining allowed number of retries (number of repeated queries before error is signaled). This parameter is also modifiable via RS-485 (register 4005) before *Master* mode is selected.

To return the RS-485 interface to the *Slave mode*, select the desired serial interface mode from the device menu: *Mbus 485* → *Mode* → *Slave*.




Fig. 23 Example: P30H transducer in Master mode used to read and store temperature from external transducer.

5.9.5 Interface RS-485 Monitor mode

RS-485 interface can operate in Monitor mode, allowing for monitoring RS-485 network traffic and react to particular response register of the selected device. P30H has to share the communication parameters with monitored devices. Serial interface Monitor mode is

enabled by selecting the following mode from menu: `Mbus 485` → `Mode` → `Monitor` or entering the value "1" to register 4042. In the `Monitor` mode, configure the following parameters in `Mbus 485` menu:

Table 35

Item	Modbus	
1	Address	Monitored device address
2	ModeUnit	Transmission mode of a link
3	Baudrate	Baud rate
4	Base.Reg	Base - monitored - register number
5	ValType	Type of monitored values
6	AnswTime	Maximum response time of monitored device [ms]

Parameters 4 - 6 can also be configured via RS-485 (registers 4048-4052) before `Monitor` mode is selected. After the `Monitor` mode is selected, transducer cannot be queried by *Master* device.

As in the `Master` mode, monitored registers are copied to the register range 8000...8049. First monitored register is copied to register 8000 and can be treated as the main displayed value. If the parameter `No.ofVal` > 1 then values of the subsequent monitored registers are put in the subsequent registers from the range 8000...8049. For example, third monitored register is to be displayed, it is necessary to set the `Display` → `Disp.Reg` parameter to „8002” or enter the „8002” value into register 4024.

To return the RS-485 interface to **Slave** mode, select proper serial interface mode from the menu: **Mbus 485 → Mode → Slave.**

5.9.6 Map of the registers

In the P30H transducer, data are placed in 16-bit and 32-bit registers. Process variables and transducer parameters are placed in the register address area in a way depending on the variable value type. Bits in 16-bit registers are numbered from the youngest to the oldest (b0 ... b15). The 32-bit registers (4 bytes) contain numbers of float type in IEEE-754 standard. Bytes sequence: B3 B2 B1 B0 – the oldest byte is transmitted as the first. 16-bit registers representing 32-bit values on two subsequent registers are duplicated in another address area with the following byte sequence: B1 B0 B3 B2 (tab. 36).

A register map of P30H transducer is shown below.

Caution: All listed addresses are physical addresses. Some computer programs use logic addressing, then the addresses should be increased by 1.

Table 36

Address range	Value type	Description
0 - 0140	integer (16 bits)	The value is located in the 16-bit register (reserved)
4000 - 4127	integer (16 bits)	The value is located in the 16-bit register.
4300 - 4325	integer (16 bits)	The value is located in the 16-bit register.
4500 - 4764	integer (16 bits)	The value is located in the 16-bit register.
6000-6198	float (32 bits)	Value set in the two following 16-bit registers. These registers contain the same data as 32-bit registers from 7500 range. Readout registers. Bytes sequence (B1,B0,B3,B2)

7000-7198	float (32 bits)	Value set in the two following 16-bit registers. These registers contain the same data as 32-bit registers from 7500 range. Readout registers. Bytes sequence (B3,B2,B1,B0)
6200 - 6337	float (32 bits)	Value set in the two following 16-bit registers. These registers contain the same data as 32-bit registers from 7600 range. Write and readout registers. Bytes sequence (B1,B0,B3,B2)
7200-7337	float (32 bits)	Value set in the two following 16-bit registers. These registers contain the same data as 32-bit registers from 7600 range. Write and readout registers.
7500-7599	float (32 bits)	The value is located in the 32-bit register. Registers are only for readout.
7600-7668	float (32 bits)	The value is located in the 32-bit register. The registers can be written and readout.
8000-8049	float (32 bits)	The value is located in the 32-bit register. The registers can be written and readout.
8100-8199	float (32 bits)	Value set in the two following 16-bit registers. These registers contain the same data as 32-bit registers from 8000 range. Write and readout registers. Bytes sequence (B3,B2,B1,B0)
8200-8299	float (32 bits)	Value set in the two following 16-bit registers. Registers contain the same data as 32-bit registers from the area 8000. The registers can be written and readout. Bytes sequence (B1,B0,B3,B2)

5.9.7 Registers for writing and readout

Table 37

The value is located in the 16-bit registers	Symbol	Write (w)/readout (r)	Range	Default value	Description
4000	VoltRang	w/ r	0...3	0	
					Value Range of voltage input
					0 12 V
					1 48 V
					2 100 V
					3 250V
4001	Rst. Coun	w/ r	0...1	0	Timer reset
					Value Description
					0 no changes
					1 Timer reset
4002	DemandTm	w/ r	0...3		Averaging time for avarage values P, U, I
					Value
					0 15-minute moving window, value not synchronized with the clock
					1 15-minute moving window, value synchronized with the clock
					2 30-minute moving window, value synchronized with the clock
					3 60-minute moving window, value synchronized with the clock
4003	Averag.				Averaging time of the instantaneous values U, I, P
					0 No averaging, value based on 8 intervals
					1 200ms
					2 500ms
					3 1s
					4 3s
					5 5s

					6	10s
4004	Syn.Time	w/ r	0...1	0	Selection of timer synchronization	
					Value	
					0	Timer off
					1	Timer permanently on
					2	Counter triggering with current threshold – when current value > value in register 7619
4005	I direct	w/ r	0...1	0	Current direction	
					Value	
					0	Normal
					1	Reversed
4006.. 4007					RESERVED	
4008	Clear En	w/ r	0...4	0	Energy counters erasing	
					0	No change
					1	Resetting the imported energy counter
					2	Resetting the exported energy counter
					3	Resetting the capacitive counter
					4	Reset of all counters
4009	Rest. AV	w/ r	0...1	0...1	Resetting the P, S, I average	
					0	No change
					1	Resetting average values
4010	TempMeas	w/ r	0...2		Temperature measurement activation	
					0	without temperature measurement
					1	measurement on the RS-485 interface operating in Master mode (register 8000)
4011					Reserved Wire resistance value for temperature measurement *100	
4012	DeltTime	w/ r			Selecting the time to indicate the differences in voltages and currents (delta U, delta I)	
					5 s	The time interval in

						determining the delta voltages and currents – 5 s
					30 s	The time interval in determining the delta voltages and currents – 30 s
					1 min	The time interval in determining the delta voltages and currents – 1 min
					5 min	The time interval in determining the delta voltages and currents – 5 min
					15 min	The time interval in determining the delta voltages and currents – 15 min
4013.... ..4015		w/ r			RESERVED	
4016		w/ r	0...3	0	Reseting maximum and minimum value	
					Value	Description
					0	no change
					1	reseting minimum values
					2	reseting maximum values
					3	reseting maximum and minimum values
4017		w/ r	0...1	0	Transducer status resetting	
					Value	Description
					0	no change
					1	status resetting
4018						
4019	Bckl.Int	w/ r	1...10	7	Value	Description
					1	Intensity of LCD display panel illumination – 10% of max. illumination
					...	
					10	Intensity of LCD display panel illumination – 100% of max. illumination
4020						
4021					RESERVED	
4022	Bcklight	w/	0.....61	61	LCD display panel illumination	

		r			Value	Description
					0	Disabled
					1...60	Disabled for 1...60 s
					61	Permanently enabled
4023					RESERVED	
4024	Disp.Reg	w/ r	0...65535	7509	Number of the register displayed on the lower display line (to display float type register value within the 16-bit registers input corresponding number of the 32-bit register)	
4025		w/ r	0...1	0	Resetting of the alarm signal support on LED (A1, A2)	
4026	Param.A1	w/ r	0...14	0	Input value controlling the alarm 1	
					Value	Description
					0	Register values 7500 - voltage
					1	Register values 7501 – current
					2	Register values 7502 – power
					3	Register values 7503
				
					11..13	reserved
					14	Register values 7514 - temperature
					15	Second value displayed
					16	Clock
4027	Type A1			0	Alarm 1 type (description – Fig. 12)	
					Value	Description
					0	n-on
					1	n-off
					2	on
					3	off
					4	h_on
					5	h_off
4028	DlyOnA1	w/ r	0...900	0	Alarm 1 activation delay time (s)	
4029	DlyOffA1	w/ r	0...900	0	Alarm 1 deactivation delay time (s)	

4039... 4041		w/ r			RESERVED	
4042	Mode	w/ r	0...2	0	Interface RS-485 operating mode	
					0	The transducer serves as Slave on the RS485 line, waiting for the queries and responds if they are addressed
					1	The transducer monitors the traffic on the RS485 line and reacts to data exchange between the external devices working as Master and Slave
					2	Transducer uses Master function on the RS-485 link, sends queries and analyzes responses received from the Slave device
4043	Address	w/ r	0...247	1	Transducer address for RS-485 interface. Entering the value "0" disables the function.	
4044	ModeUnit	w/ r	0...3	0	Interface RS-485 transmission mode	
					0	RTU 8N2
					1	RTU 8E1
					2	RTU 8O1
					3	RTU 8N1
4045	BaudRate	w/ r	0...7	1	RS-485 interface baud rate	
					Value	Description
					0	4800 bit/s
					1	9600 bit/s
					2	19200 bit/s
					3	38400 bit/s
					4	57600 bit/s
					5	115200 bit/s
					6	230400 bit/s
					7	256000 bit/s
4046	Mast. Fun	w/ r	0...1	0	Modbus protocol function used by the transducer working with RS-485 interface in Master mode	
					0	function 0x03

					1	function 0x04
4047	No.OfErr	w/ r	0...10	2	Allowed number of errors in the RS-485 interface Master mode	
4048	AnswTime	w/ r	10...500 0	100 0	Maximum time until response in serial interface Master and Monitor modes [ms]	
4049	ValType	w/ r	0...12	6	Type of values queried/monitored in serial interface Master or Monitor mode	
					char 8	Register type <i>char</i> (8 bits signed)
					uchar 8	Register type <i>unsigned char</i> (8 bits unsigned)
					short 16	Register type <i>short</i> (16 bits signed)
					ushort16	Register type <i>unsigned short</i> (16 bits unsigned)
					long 32	Register type <i>long</i> (32 bits signed)
					ulong 32	Register type: <i>unsigned long</i> (32 bits unsigned)
					flt 32	Register type <i>char</i> (32 bits, signed variable comma)
					sflt2x16	Register type: swapped <i>float</i> , value in two 16-bit registers (byte sequence 3,2,1,0)
					flt 2x16	Register type: <i>float</i> , value in two 16-bit registers (byte sequence 1,0,3,2)
					lng 2x16	Register type <i>long</i> , value in two 16-bit registers (32 bits signed, byte sequence 1,0,3,2)
					slng2x16	Register type <i>swapped long</i> , value in two 16-bit registers (32 bits signed, byte sequence 3,2,1,0)
					ulng2x16	Register type <i>unsigned long</i> , value in two 16-bit registers (32 bits unsigned, byte sequence 1,0,3,2)
					uSlng2x16	Register type <i>unsigned swapped long</i> , value in two

					16-bit registers (32 bits unsigned, byte sequence 3,2,1,0)
4050	Base. Reg	w/ r	0...65535	7510	Number of the base register queried/monitored in the RS-485 interface Master or Monitor mode
4051	No. ofVal	w/ r	0...50	1	Number of values queried/monitored in serial interface Master or Monitor mode
4052	Interv.	w/ r	1...36000	10	Query period for the device in RS-485 Master mode
4053		w/ r	0...1	0	Transmission parameters update. It uses the entered settings of RS-485 interface.
4054	Language	w/ r	0...3	0	Transducer language menu:
					Value Description
					0 Polish
					1 English
4055	Fabr. Par	w/ r	0...1	0	Standard parameters saving
					Value Description
					0 No change
					1 Standard parameters setting
4056	Security	w/ r	0...9999	0	Password for parameters setting
					Value Description
					0 No change
					... Enters the parameters setting menu after accepting the correct password.
4057	Time	w/ r	0...2359	-	Current time – hours, minutes This parameter is given in ggmm format, where: gg - stands for hours, mm – stands for minutes. Entering incorrect value (out of range) results in setting the value 23 for hours and 59 for minutes. After the save is completed, register 4055 (seconds) is zeroed.
4058		w/ r	0...60	-	Current time – seconds
4059		r	0...100	-	Current time – 1/100 second
4060	Date	w/	101...12	-	Current date in month*100 + day format

		r	31		
4061		w/ r	2001... 2099	-	Current year in YYYY format.
4062		w/ r	0...1	0	Automatic DST and inversely
					Value Description
					0 Off
					1 On
4063		w/ r			RESERVED
4064	Arch. Val	w/ r	0... 65535	0	Selecting archived values Caution: <u>change of register value will result in deletion of the internal memory archive!</u>
					Value Description
					0x0001 Bit 1 – registry 7500 value registration
					0x0002 Bit 2 – registry 7501 value registration
					0x0004 Bit 3 – registry 7502 value registration
					0x0008 Bit 4 – registry 7503 value registration
				
					Second value displayed
					0x7FFF Registration of register value 7500...7514 + second displayed value
4065	Param. Ar	w/ r	0...16	0	Value controlling conditional archiving trigger
					Value Description
					0 Register values 7500 - voltage
					1 Register values 7501 – current
					2 Register values 7502 – power
					3 Register values 7503 – reactive power
				
					11...13 reserved
					14 Register values 7514 - temperature

					15	Second value displayed
					16	Clock
4066	Ar. Mode	w/ r	0...5	5	Archiving type (description – Fig. 18)	
					Value	Description
					0	n-on
					1	n-off
					2	on
					3	off
					4	h_on
					5	h_off
4067	Ar. Time	w/ r	1...3600	10	Archiving period in seconds	
4068	Ar. Erase	w/ r	0...1	0	Deleting an internal archive	
4069	Rec. ToSD	w/ r	0...1	0	Saving of the internal archive to SD/SDHC card	
					Value	Description
					0	No action
					1	Start of internal archive saving to SD/SDHC card
4070		w/ r	0...1	0	Decimal point selection for archive files	
					Value	Description
					0	comma
					1	dot
4071.... ..4077		w/ r			RESERVED	
4078	SaveFile	w/ r	0...2	0	Value	Description
					0	No action
					1	Transducer configuration saving to P30H_PAR.CON file on the external SD/SDHC card or in the file system internal memory
					2	Transducer configuration readout from P30H_PAR.CON file on the external SD/SDHC card or in the file system internal memory

4079		w/ r		-	RESERVED
4080	EthStdPa	w/ r	0...1	0	Setting the new parameters of Ethernet interface
					Value Description
					0 No change
					1 Restoring the default parameters of Ethernet interface
4081	addr IP32	w/ r	0...6553 5	493 20	The third and the second byte (B3.B2) of the IP address of the transducer, the IPv4 address format: B3.B2.B1.B0
4082	addr IP10	w/ r	0...6553 5	286	The first and zero byte (B1.B0) of the IP address of the transducer, the IPv4 address format: B3.B2.B1.B0
4083	mask 32	w/ r	0...6553 5	655 35	The third and the second byte (B3.B2) of the transducer subnet mask, mask format: B3.B2.B1.B0
4084	mask 10	w/ r	0...6553 5	652 80	The first and zero byte (B1.B0) of the transducer subnet mask, the mask format: B3.B2.B1.B0
4085	MAC 54	r	0...6553 5	-	The fifth and fourth byte (B5.B4) of the transducer MAC address, format B5:B4:B3:B2:B1:B0
4086	MAC 32	r	0...6553 5	-	The third and the second byte (B3.B2) of the transducer MAC address, format B5:B4:B3:B2:B1:B0
4087	MAC 10	r	0...6553 5	-	The first and zero byte (B1.B0) of the transducer MAC address, format B5:B4:B3:B2:B1:B0
4088	Gate 32	w/ r	0...6553 5	493 20	The third and the second byte (B3.B2) of the transducer default gateway, the gateway address format: B3.B2.B1.B0
4089	Gate 10	w/ r	0...6553 5	257	The first and zero byte (B1.B0) of the transducer default gateway, the gateway address format: B3.B2.B1.B0
4090	DHCP	w/ r	0...1	1	Enabling/disabling the DHCP Client (supports automatic obtaining of IP protocol parameters of the transducer Ethernet interface from external DHCP servers in the same LAN)
					Value Description
					0 DHCP disabled - you should

					manually configure the IP address and subnet mask of the transducer;	
					1	DHCP enabled, the transducer will automatically receive the IP address, subnet mask, and gateway address from the DHCP server when switching the supply on or selecting ReInitEt option from the menu or entering the value "1" to the register 4099; the gateway address is the address of the server that assigned the parameters to the transducer;
4091	10/100Mb	w/ r	0...2	0	Baud rate of the Ethernet interface:	
					Value	Description
					0	Automatic selection of the baud rate
					1	10 Mb/s
					2	100 Mb/s
4092	p.comFTP	w/ r	20... 65535	21	FTP server commands port number	
4093	Port FTP	w/ r	20... 65535	102 5	FTP server data port number	
4094	no.c.TCP	w/ r	1...4	4	The maximum simultaneous connections to Modbus TCP/IP service	
4095	TimeMbus	w/ r	10...600	60	Port closing time of Modbus TCP/IP service, in seconds	
4096	AddrnTCP	w/ r	0...255	1	Device address for Modbus TCP/IP protocol	
4097	PortMbus	w/ r	0... 65535	502	Modbus TCP port number	
4098	PortHTTP	w/ r	80...655 35	80	Web server port number	
4099	ReInitEt	w/ r	0...1	0	Saving the new parameters and initiate Ethernet interface	
					Value	Description
					0	No change
					1	Saving the new parameters and

						initiate Ethernet interface
4100	ParamAn1	w/ r	0..16	7	Input value controlling the analog output 1	
					Value	Description
					0	Register values 7500 - voltage
					1	Register values 7501 – current
					2	Register values 7502 – power
					3	Register values 7503
				
					14	Register values 7514 - temperature
					15	Second value displayed
					16	Clock
4101	OverSer1	w/ r	0...1	0	Analog output 1 overrun support	
					Value	Description
					0	Off
					1	On
4102	OvOutLo1	w/ r	0...2400 0	0	Output 1 lower overrun value x1000	
4103	OvOutHi1	w/ r	0...2400 0	200 00	Output 1 upper overrun value x1000	
4104	OvrOutL1	w/ r	0...2400 0	0	Output 1 expected value when its lower limit is exceeded x1000	
4105	OvrOutH1	w/ r	0...2400 0	0	Output 1 expected value, when its upper limit x1000 is exceeded	
4106	Param.A2	w/ r	0..16	0	Input value controlling the analog output 2 (option)	
					Value	Description
					0	Register values 7500 - voltage
					1	Register values 7501 – current
					2	Register values 7502 – power
					3	Register values 7503
				
					14	Register values 7514 - temperature
					15	Second value displayed
					16	Clock

4107	OverSer2	w/ r	0...1	0	Analog output 2 overrun support	
					Value	Description
					0	Off
					1	On
4108	OvOutLo2	w/ r	0...2400 0	0	Output 2 lower overrun value x1000	
4109	OvOutHi2	w/ r	0...2400 0	200 00	Output 2 upper overrun value x1000	
4110	OvrOutL2	w/ r	0...2400 0	0	Output 2 expected value, when its lower limit x1000 is exceeded	
4111	OvrOutH2	w/ r	0...2400 0	0	Output 2 expected value, when its upper limit x1000 is exceeded	
4112... 4127		w/ r			RESERVED	

Table 38

The value is located in the 16-bit registers.	Write (w)/readout (r)	Range	Default value	Description
4500	w/r	0...7712	0	Number of the memory page being accessed. Page number saving
4501	r	0...6553 5	-	First two bytes from the page indicated by 4500 register.
4502	r	0...6553 5	-	Two subsequent bytes
---	---	---	-	---
4764	r	0...6553 5	-	Two last bytes of a memory page (bytes 526 and 527)

Table 39

Value set in the two following 16-bit registers. Registers contain the same data as 32-bit registers from the area 7600.	The value is located in 32-bit registers.	Symbol	Write (w)/readout (r)	Range	Default value	Description
6200/7200	7600	OverLoA1	w/r	-9.9999e13 ...99999e13	0	Alarm 1 lower limit
6204/7202	7601	OverHiA1	w/r	-9.9999e13 ...99999e13	20	Alarm 1 upper limit
6206/7204	7602	OverLoA2	w/r	-9.9999e13 ...99999e13	0	Alarm 2 lower limit
6208/7206	7603	OverHiA2	w/r	-9.9999e13 ...99999e13	20	Alarm 2 upper limit
6210/7208	7604	OverLoAr	w/r	-9.9999e13 ...99999e13	0	Lower limit of conditional archiving
6212/7210	7605	OverHiAr	w/r	-9.9999e13 ...99999e13	20	Upper limit of conditional archiving
6214/7212	7606	AnIn Lo1	w/r	-9.9999e13 ...99999e13	0	Individual characteristic of analog output 1- lower limit of the controlling value
6214/7214	7607	AnIn Hi1	w/r	-9.9999e13 ...99999e13	100	Individual characteristic of analog output 1 - upper limit of controlling value
6214/7216	7608	AnOutLo1	w/r	0...24	0	Individual characteristic of analog output 1- lower limit of the controlling value
6218/7218	7609	AnOutHi1	w/r	0...24	20	Individual characteristic of analog output 1- upper limit of the controlling value
6220/7220	7610	AnIn Lo2	w/r	-9.9999e13 ...99999e13	0	Individual characteristic of analog output 2- lower

						limit of the controlling value
6222/7222	7611	AnIn Hi2	w/r	-9.9999e13 ...99999e13	100	Individual characteristic of analog output 2 - upper limit of controlling value
6224/7224	7612	AnOutLo2	w/r	0...24	0	Individual characteristic of analog output 2- lower limit of the controlling value
6226/7226	7613	AnOutHi2	w/r	0...24	20	Individual characteristic of analog output 2- upper limit of the controlling value
6228.. 6235/7228 ..7235	7614... 7617				0	RESERVED
6236/7236	7618	Param. SD	w/r	0.05 ... 95	50	The percentage of the internal archive space used which triggers automatic writing on SD/SDHC card
6238/7238	7619	CurrThrs	w/r	-99999G ...99999G		Current threshold above which time is counted
6240/7240	7620	Primar. U	w/r	0.0001... 99999G		Input voltage (included when calculating the rescaling ratio)
6242/7242	7621	Second. U	w/r	0.0001... 99999G		Output voltage (included when calculating the rescaling ratio)
6244/7244	7622	Shunt I	w/r	0.0001... 99999G		Shunt nominal current
6246/7246	7623	Shunt mV	w/r	0.0001... 99999G		Voltage corresponding to the shunt nominal current [mV]
6248... 6258/ 7248... 7258	7624... 7629					RESERVED

Table 40

Value set in the two following 16-bit registers. Registers contain the same data as 32-bit registers from the area 8000.	The value is located in the 32-bit registers.	Write (w)/ readout (r)	Quantity name
8100/8200	8000	w/r	The value of the 1st register readout by the transducer operating in serial interface Master or Monitor mode
8102/8202	8001	w/r	The value of the 2nd register readout by the transducer operating in serial interface Master or Monitor mode
8104/8204	8002	w/r	The value of the 3rd register readout by the transducer working in serial interface Master of Monitor mode
8106...8197 / 8206...8297	8003... ...8049		The value of the nth register readout by the transducer operating in serial interface Master or Monitor mode
8198/8298	8049	w/r	The value of the 50th register readout by the transducer operating in serial interface Master or Monitor mode

5.9.8 Registers for readout

Table 41

The value is located in the 16-bit registers.	Write (w)/readout (r)	Range	Description
4300	r	0...9999	Software version * 100
4301	r	0...9999	Bootloader version * 100
4302	r	0...65535	Status no. 1 of the transducer. Describes the current status of the transducer. Successive bits represent the event. Bit set to 1 indicates that the event took place. The events can be only deleted.
			Bit15 31 Loss of the calibration parameters
			Bit14 30 Real Time Clock – loss of settings – battery

				failure
			Bit13 29	Clock – daylight saving on/off
			Bit12 28	No communication with data memory
			Bit11 27	Invalid settings
			Bit10 26	Default settings restored
			Bit9 25	
			Bit8 24	Internal archive communication error
			Bit7 23	Archive parameters error
			Bit6 22	
			Bit5 21	Internal archive 100% full
			Bit4 20	Reset to default settings necessary
			Bit3 19	
			Bit2 18	not used
			Bit1 17	not used
			Bit0 16	not used
4303	r	0...65535	Status no. 2 of the transducer. Describes the current status of the transducer. Successive bits represent the event. Bit set to 1 indicates that the event took place. The events can be only deleted.	
			Bit15	not used
			Bit14	not used
			Bit13	not used
			Bit12	not used
			Bit11	not used
			Bit10	not used
			Bit9	not used
			Bit8	not used
			Bit7	not used
			Bit6	Overrun of output 1 enabled
			Bit5	LED2 – Alarm signal no. 2.
			Bit4	LED1 – Alarm signal no. 1.
			Bit3	not used
			Bit2	not used
			Bit1	State of the alarm 2 relay.
			Bit0	State of the alarm 1 relay.
4304	r	0...5	Memory card status	

			Value	Description
			0	No card
			1	The card inserted but not installed (uninstalled).
			2	Card inserted but the attempt failed.
			3	The card inserted, installed correctly but write-protected. The card is uninstalled automatically when write-protection is detected.
			4	The card inserted and installed.
			5	The card inserted and installed but full.
			6	Card being installed
4305	r		Measurement status	
			bit 0...6	reserved
			bit 7	„1” - voltage signal lower than measurement threshold
			bit 8	„1” - current signal lower than measurement threshold
			bit 9	„1” - voltage signal higher than measurement threshold
			bit 10	„1” - current signal higher than measurement threshold
			bit 11...15	reserved
4306	r		Ethernet interface status	
			bit 0	„1” transducer equipped with the Ethernet system
			bit 1	„1” - automatic link parameter negotiation ongoing
			bit 2	„1” - automatic negotiation successfully completed
			bit 3	„1” - connection completed successfully
			bit 4	„1” - connection parameters acquired from DHCP server
			bit 5	„1” - connection parameter should be refreshed by DHCP server
			bit 6	„1” - Ethernet interface cables successfully connected
			bit 7	„1” - FTP connection successfully completed
			bit 8	„1” - Ethernet interface in energy saving mode

			bit 9	reserved
			bit 10	„1” - Ethernet interface clock - correct operation „0” - no signal for Ethernet interface clock
			bit11...bit 15	reserved
4307	r		reserved	
4308	r		Production status 1	
			Bit15 ... Bit0	Serial number (1...99999)
4309	r		Production status 2	
			Bit15 ... Bit12	RESERVED
			Bit11 ... Bit6	Year of production (0...63)
			Bit5 ... Bit0	Month of production (0...12)
4310	r		Production status 3	
			Bit15 ... Bit14	„01” - high power „10” - low power
			Bit13 ... Bit11	„01” - output no. 2 – N/O relay „10” - output no. 2 – out Power 24 VDC
			Bit10 ... Bit8	„001” - output no. 2 – N/O relay „010” - output no. 2 – analog current output „011” - output no. 2 – analog voltage output
			Bit7 ... Bit5	„000” – accessories – no ext. SD slot, no Ethernet „001” – accessories - ext. SD slot, no Ethernet „010” – accessories - Ethernet interface with internal memory
			Bit4 ... Bit3	„001” - voltage output in 100 VAC range „010” - voltage output in 230 VAC range
			Bit2 ... Bit0	reserved
4311	r		Production status 4	
			Bit15 ... Bit7	reserved
			Bit6	„0” - Polish language version „1” - English language version
			Bit5 ... Bit0	reserved
4312	r	0...8192	Memory page indicating start of archive	

4313	r	0...8192	Memory page indicating end of archive	
4314	r	0...527	Byte indicating start of archive. Register value indicates the byte on the archive start page marking the start of archive.	
4315	r	0...527	Byte indicating end of archive. Register value indicates the subsequent byte where the archive record will be written.	
4316.. ...4329			RESERVED	
4330	r	0...65535	Imported energy, 2 older bytes	Value type long , [0,1*kW], 4 unfeigned bytes (0...199999999)
4331	r	0...65535	Imported energy, 2 younger bytes	
4332	r	0...65535	Exported energy, 2 older bytes	Value type long , [0,1*kW], 4 unfeigned bytes (0...99999999)
4333	r	0...65535	Exported energy, 2 younger bytes	
4334	r	0...65535	Sum of energy (imported and exported), 2 older bytes	Value type long , [0,1*kW], 4 unfeigned bytes (0...199999999)
4335	r	0...65535	Sum of energy (imported and exported), 2 younger bytes	
4336	r	0...65535	Capacity, 2 older bytes	Value type long , 4 feigned bytes [0,1*kAh] (-49999999 ... 49999999)
4337	r	0...65535	Capacity, 2 younger bytes	
4338	r	0...65535	Timer [s], 2 older bytes	Value type long , 4 unfeigned bytes [s] (0...999999999)
4339	r	0...65535	Timer [s], 2 younger bytes	
4340	r	0...65535	Difference of energy (imported and exported), 2 older bytes	Value type long , 4 feigned bytes [0,1*kWh] (- 99999999 ... 99999999)
4341	r	0...65535	Difference of energy (imported and exported), 2 younger bytes	

**Example for reading of energy values from registers 43xx –
reading of energy difference (imported and exported) (registers
4340, 4341) – positive value**

values read from the registers are:

reg. 4340 → hexadecimal value: 0x027A (2 older value bytes)

reg. 4341 → hexadecimal value: 0xF3E0 (2 younger value bytes)

we make 4 bytes value (feigned total value):

hexadecimal value: 0x027AF3E0 → decimal value: 41612256

[0,1*kWh] = 4 161 225,6 [kWh]

Example for reading of energy values from registers 43xx – reading of energy difference (imported and exported) (registers 4340, 4341) – negative value

values read from the registers are:

reg. 4340 → hexadecimal value: 0xFF44 (2 older value bytes)

reg. 4341 → hexadecimal value: 0x00BB (2 younger value bytes)

we make 4 bytes value (feigned total value):

hexadecimal value: 0xFF4400BB → decimal value: -12320581

[0,1*kWh] = -1 232 058,1 [kWh]

Table 42

Value set in the two following 16-bit registers. Registers contain the same data as 32-bit registers from the area 7500.	The value is located in the 32-bit registers.	Name	Write (w)/readout (r)	Unit	Quantity name
6000/7000	7500	U	r	V	Voltage
6002/7002	7501	I	r	A	Current
6004/7004	7502	P	r	W	power
6006/7006	7503	dU	r	V	Delta voltage in the time interval
6008/7008	7504	dI	r	A	Delta current in the time interval
6010/7010	7505	t [s]	r	s	Timer in seconds
6012/7012	7506	t [H.M]	r		Timer in hours, minutes
6014/7014	7507	C	r	Ah	Capacity

6016/7016	7508	PAV	r	W	Average power 15, 30, 60 minutes
6018/7018	7509	UAV	r	V	AverageVoltage 15, 30, 60 minutes
6020/7020	7510	IAV	r	A	Avarage current 15, 30, 60 minutes
6022/7022	7511				Reserved
6024/7024	7512				Reserved
6026/7026	7513				Reserved
6028/7028	7514	T	r	C	Temperature (optional)
6030/7030	7515	$E_{P\leftarrow}$	o	Wh	Imported energy (0... 99,999 G)
6032/7032	7516	$E_{P\rightarrow}$	o	Wh	Exported energy (0... 99,999 G)
6034/7034	7517	E_T	o	Wh	Sum of energy (imported and exported) (0... 199,999 G)
6036/7036	7518	C	o	Ah	Capacity (-49,999 G ... 49,999 G)
6038/7038	7519	En		Wh	Difference of energy (imported and exported) (-99,999 G ... 99,999 G)
6040/7040	7520	$E_{P\leftarrow}$	r	100 MWh	Imported energy (no. of register 7521 overflows, resets to 0 after reaching 99999999.9 kWh)
6042/7042	7521	$E_{P\leftarrow}$	r	kWh	Imported energy (counter counting up to 99999.9 kWh)
6044/7044	7522	$E_{P\rightarrow}$	r	100 MWh	Exported energy (no. of register 7523 overflows, resets to 0 after reaching 99999999.9 kWh)
6046/7046	7523	$E_{P\rightarrow}$	r	kWh	Exported energy (counter counting up to 99999.9 kWh)
6048/7048	7524	ET	r	100 MWh	Sum of energy (imported and exported) (no. of register 7525 overflows, resets to 0 after reaching 199999999,9 kWh)
6050/7050	7525	ET	r	kWh	Sum of energy (imported and exported) (counter counting up to 99999,9 kWh)
6052/7052	7526	C	r	100 MAh	Capacity (no. of register 7527 overflows, resets to 0 after reaching $\pm 49999999,9$ kAh)
6054/7054	7527	C	r	kAh	Capacity (counter counting from -99999,9 up to 99999,9 kAh)
6056/7056	7528	En	r	100 MWh	Difference of energy (imported and exported) (no. of register 7529 overflows, resets to 0 after reaching $\pm 99999999,9$ kWh)

6058/7058	7529	En	r	kWh	Difference of energy (imported and exported) (counter counting from -99999,9 up to 99999,9kWh)
6060/7060	7530				Reserved
6062/7062	7531				Reserved
6064/7064	7532	U_{MIN}	r	V	Minimum voltage
6066/7066	7533	U_{MAX}	r	V	Maximum voltage
6068/7068	7534	I_{MIN}	r	A	Minimum current
6070/7070	7535	I_{MAX}	r	A	Maximum current
6072/7072	7536	P_{MIN}	r	W	Min. power
6074/7074	7537	P_{MAX}	r	W	Max. power
6076/7076	7538	dU_{MIN}	r	V	Delta voltage minimum
6078/7078	7539	dU_{MAX}	r	V	Delta voltage maximum
6080/7080	7540	dI_{MIN}	r	A	Delta current minimum
6082/7082	7541	dI_{MAX}	r	A	Delta current maximum
6084/7084	7542				Reserved
6086/7086	7543				Reserved
6088/7088	7544				Reserved
6090/7090	7545				Reserved
6092/7092	7546	C_{MIN}	r	Ah	Capacity minimum
6094/7094	7547	C_{MAX}	r	Ah	Capacity maximum
6096/7096	7648	PDM_{MIN}	r	W	power averaged 15, 30, 60 minutes, min.
6098/7098	7549	PAV_{MAX}	r	W	power averaged 15, 30, 60 minutes, max.
6100/7100	7550	UAV_{MIN}	r	V	voltage averaged 15, 30, 60 minutes, min.
6102/7102	7551	UAV_{MAX}	r	V	voltage averaged 15, 30, 60 minutes, max.
6104/7104	7552	$I_{\text{AV}}_{\text{MIN}}$	r	A	Current averaged 15, 30, 60 minutes, min.
6106/7106	7553	$I_{\text{AV}}_{\text{MAX}}$	r	A	Current averaged 15, 30, 60 minutes, max.
6108/7108	7554				Reserved
6110/7110	7555				Reserved
6112/7112	7556				Reserved
6114/7114	7557				Reserved

6116/7116	7558				Reserved
6118/7118	7559				Reserved
6120/7120	7560	T _{MIN}	r	C	Temperature min. (optional)
6122/7122	7561	T _{MAX}	r	C	Temperature max. (optional)
6124...6139 / 7124...7139	7562 ...7569				RESERVED
6140/7140	7570	ID	r	-	Constant value identifying the device The value of 196 represents P30H transducer.
6142/7142	7571	Status	r	-	Register describing current transducer state - register value 4302 „Status no. 2”.
6144/7144	7572	Output 1 actuated	r	%	The register linked to the analog output 1 activation.
6146/7146	7573	Output 2 actuated	r	%	The register linked to the analog output 2 activation.
6148/7148	7574	Output 3 actuated	r	%	The register linked to the analog output 3 activation.
6150/7150	7575	Displayed value	r	-	Currently displayed value
6152/7152	7576	Displayed value multiplier	r	-	Exponent of displayed value multiplier
6154/7154	7577	Current time	r	-	Current time
6156/7156	7578	Date - year	r	YYYY	Current date - year
6158/7158	7579	Month, day	r	MMDD	Current date – month, day
6160/7160	7580	Archive fill rate	r	%	Current internal archive memory fill rate
6162/7162	7581		r	-	reserved
6164/7164	7582	Second value displayed	r		Value displayed on lower LCD line - any register value
6166/7166	7583		r		Free space on SD/SDHC card (kB), value „-1” means no card installed

6168/7168	7584		r		Total space on SD/SDHC card (kB), value „-1” means no card installed
6170...6172 / 7170...7172	7585... 7586				RESERVED
6174/7174	7587	Analog value	r	-	Numerical value controlling the analog output 1 of the transducer
6176/7176	7588	Analog value	r	-	Numerical value controlling the analog output 2 of the transducer
6178/7178	7589	Analog value	r	-	Numerical value controlling the analog output 3 of the transducer
6180...6182 / 7180...7182	7590...7 591				RESERVED
6184/7184	7592	Status no. 1	r	-	Register value 4301 projected onto the floating-point value
6186/7186	7593	Status no. 1			Register value 4302 projected onto the floating-point value
6188/7188	7594		r	-	RESERVED
6190/7190	7595		r		Rescaling value on voltage input
6192/7192	7596		r		Rescaling value on current input
6194..6198 /7194..7198	7597... 7599				RESERVED

Example for reading of energy values from registers 7520...7529 – reading of energy difference (imported and exported) (registers 7528, 7529) – positive value

values read from the registers are:

reg. 7528 → decimal value (float): 41,0 → no. of register 7529 overflows →
N = 41

reg. 7529 → decimal value (float): 61225,6 → counter → C = |61225,6| =
61225,6; energy sign → S „+”

energy value $E_N = S(N \cdot 100 \text{ MWh} + C) = +(41,0 \cdot 100 \cdot 1000 \text{ kWh} + 61225,6) =$
4 161 225,6 [kWh]

Example for reading of energy values from registers 7520...7529 – reading of energy difference (imported and exported) (registers 7528, 7529) – negative value

values read from the registers are:

reg. 7528 → decimal value (float): 12,0 → no. of register 7529 overflows →
N = 12

reg. 7529 → decimal value (float): -32087,3 → counter → $C = |-32087,3| = 32087,3$; energy sign → S „-“
 energy value $E_N = S(N * 100 \text{ MWh} + C) = - (12 * 100 * 1000 \text{ kWh} + 32087,3) = - 1\,232\,087,3 \text{ [kWh]}$

5.10. Ethernet interface 10/100-BASE-T

P30H transducers in P30H-XX2XXXXXX version are equipped with an Ethernet interface for connecting the device (using the RJ45 socket) to the local or global network (LAN or WAN) and using transducer's net services: web server, FTP server, Modbus slave TCP/IP. Configure Ethernet group parameters to use the transducer network services. Standard Ethernet parameters of the transducer are shown in Tab. 15. IP address is the main web parameter of the transducer, by default it is 192.168.1.30, but must set to unique value within a network the device is connected to. The IP address can be assigned to the transducer automatically by the DHCP server present in the network if the transducer has an option to obtain an address from DHCP server enabled: Ethernet → DHCP → On. If the DHCP service is disabled then the transducer will work with the default IP address allowing the user to change the IP address, e.g. from the transducer menu. Every change of transducer's Ethernet parameters requires confirmation of the parameter change, e.g. from Ethernet → ReInitEt → Yes menu or by entering value "1" into register 4099. The Ethernet interface is rebooted in accordance with the new parameters after applying changes - all services of the Ethernet interface are restarted.

Note: Transducer allows for up to 4 simultaneous connections! Applications prebuilt in the transducer use 1 or 2 connections:

- modbus TCP/IP - 1 connection
- web server - 1 connection
- FTP server - 2 connections

5.10.1 Connecting 10/100-BASE-T interface

Connect the device to a TCP/IP network using the RJ45 socket located at the front of the transducer to access the Ethernet services.




Fig. 24 View and pin numbering of the RJ45 socket

RJ45 socket LEDs description:

- yellow LED lights up when the transducer is properly connected to the Ethernet 100 Base-T and is off when the transducer is not connected to a network or is connected to a 10-Base-T.
- green LED Tx/Rx, blinks irregularly whenever the transducer is sending and receiving data, lights up continuously when no data is transmitted

It is recommended to use a twisted pair cable to connect the transducer to the network:

- U/FTP – twisted pair cable with a separate foil for every pair
- F/FTP – twisted pair cable with separate foil for every pair and additional foil shielding for the cable

- S/FTP (former SFTP) – twisted pair cable with separate foil for every pair and additional mesh cable shielding
- SF/FTP (former S-STP) – twisted pair cable with separate foil for every pair and additional mesh and foil cable shielding

The twisted pair cable categories according to the European standard EN 50171 are minimum: Class D (category 5) - for high-speed local area networks, includes the applications using the frequency band up to 100 MHz. Connection was described in Tab. 44. For Ethernet connection use the category 5 STP type twisted-pair cable (shielded) with RJ-45 connector, wiring colors (according to Tab. 43), compliant with the following standards:

- EIA/TIA 568A for both connectors in strike-through connection between P30H and hub or switch,
- EIA/TIA 568A for the first connector and EIA/TIA 568B for the second one in the cross-over connection (i.e. when connecting the P30H transducer to the PC).

Table 43

Wire no.	Signal	Wire color according to the standard	
		EIA/TIA 568A	EIA/TIA 568B
1	TX+	white-green	white-orange
2	TX-	green	orange
3	RX+	white-orange	white-green
4	EPWR+	blue	blue
5	EPWR+	white-blue	white-blue
6	RX-	orange	green
7	EPWR-	white-brown	white-brown
8	EPWR-	brown	brown

5.10.2 Web Server

P30H transducer provides its own web server which enables remote monitoring of the measuring values, remote configuration and reading a transducer status. A web page allows in particular to:

- obtain information about the device (serial number, code execution, software version, bootloader version, version (standard or special))
- preview current measuring values
- read a device status
- select the web page language

You can access the web server via web browser by entering the IP address of the transducer, e.g.: `http://192.168.1.30` (where 192.168.1.30 is current IP address of the meter). The default web server port is the port "80". The server port can be changed by the user.

Note: A browser with JavaScript enabled and compatible with XHTML 1.0 is required for correct operation of the website (all popular browsers, Internet Explorer version 8 minimum).

5.10.2.1. General view

Transducer P30H

Measured values
Input parameters
Analog outputs
Alarms
RS-485 Modbus
Display settings
Archive
Ethernet
Service parameters

About P30H
Logout (user)

Measured values : standard params.					
Parameter	Value	Parameter	Value	Parameter	Value
U	2.696 V	I	0.190 A	P	0.513 W
dU	0.000 V	dI	0.010 A	t [s]	168335.000 s
t [H.M]	46.453	C	169.293 Ah	P _{DM}	0.495 W
U _{DM}	2.696 V	I _{DM}	0.184 A	T	***** C

Measured values : energy counters	
Parameter	Value
Ep+	2.201 kWh
Ep-	0.000 kWh
E	0.220 kWh
C	0.169 kWh

Measured values : min/max params.					
Parameter	Min	Max	Parameter	Min	Max
U	2.570 V	2.717 V	I	-0.422 A	0.653 A
P	-1.101 W	1.706 W	dU	-0.021 V	2.591 V
dI	-0.329 A	0.365 A	C	82.231 Ah	169.293 Ah
P _{DM}	0.000 W	0.535 W	U _{DM}	0.000 V	2.696 V
I _{DM}	0.000 A	0.198 A	Temp.	***** C	***** C

Erase extremum


Fig. 25 Transducer WWW page

5.10.2.2. Web user selection

The transducer has two user accounts for the web server protected by the individual passwords:

- user: „**admin**”, password: „**admin**” - access to the configuration and preview of the parameters
- user: „**user**”, password: „**pass**” - access to parameters preview only.

Entering the transducer IP address into a browser, e.g. <http://192.168.1.30> will display a startup website to enter the user name and password.



Transducer P30H

Login

Username

Password

Login

Fig.26 View of the transducer web server login window

The web server user names can not be changed but you can change the password for each user - for safety reasons it is recommended to change the passwords. Changing the password is possible only through a web page in the "Ethernet" parameter group. The passwords can be up to 8 characters. If the password is lost (what disables using the web server), restore the default settings of the Ethernet interface e.g. from the menu: Ethernet → EthStdPa → Yes, or by entering the value "1" to the register 4080. All standard Ethernet interface parameters (see Tab. 15) and the passwords of the FTP server users will be restored: Table 15

user „**admin**” → password: „**admin**”;

user "**user**" → password "**pass**".

The session lasted five minutes opens when you log in to the web server. After five minutes a user will be automatically logged out

from a web server. The change of the group parameters renews time to expiry of the session.

5.10.3 FTP Server

The FTP file sharing protocol has been implemented in the P30H transducers. The transducer acts as a server, allowing the users to access the internal memory of its file system. Access to the files is possible using a computer, a tablet with installed FTP client or other device acting as a FTP client. The standard FTP ports are used for transferring files, "20" - data port and "21" -- commands port. A user can change the port used by the FTP protocol if necessary. Please note, that the port configuration of the FTP server and the client must be the same.

It is recommended to set the FTP client in the passive mode, because the connection is then fully configured by the FTP client (a client chooses the data port). Only one connection at one time can be used for the file transfer, so the maximum number of a FTP client connections should be set to "1".

5.10.3.1. FTP user selection

The transducer has two FTP server user accounts protected by individual passwords:

- user: „**admin**”, password: "**admin**" - access to read and write the files
- user: „**user**", password: "**passftp**" - access to read only the archive files.

The FTP user names can not be changed but you can change the password for each user - for safety reasons it is recommended to change the passwords. Changing the password is possible only through a web page in the "Ethernet" parameter group. The passwords can be up to 8 characters. If the password is lost (what disables using the FTP server), restore the default settings of the Ethernet interface e.g. from the menu: Ethernet → EthStdPa → Yes, or by entering the value "1" to the register 4080. All standard Ethernet interface parameters (see Tab. 15) and the passwords of the FTP server users will be restored: Table 15

user „**admin**” → password: „**admin**”;

user "**user**" → password "**passftp**".

Internet browser can be used as a rudimentary FTP client. By entering the IP address of transducer with the “ftp” header into the address field, e.g.: <ftp://192.168.1.30> it is possible to browse and download archive files from the Internet browser directly.




Fig. 27 View of the FTP session in browser window

5.10.4 Modbus TCP/IP

P30H transducers allow access to the internal registers via the Ethernet interface and Modbus TCP/IP Slave protocol. Modbus protocol functions and register structure are described in section 5.9.3 - 5.9.6. It is necessary to set the unique IP address of the transducer and the connection parameters listed in Tab.44 to set up a connection.

Table 44

Symbol	Description	Default value
AddrnTCP	Device address for Modbus TCP/IP protocol	1
PortMbus	Modbus TCP port number	502
TimeMbus	Port closing time of Modbus TCP/IP service [s]	60
no.c.TCP	The maximum simultaneous connections to Modbus TCP/IP service	2

Device address (Ethernet → AddrnTCP) is Modbus TCP/IP protocol device address and is not identical to the corresponding value of Modbus RS-485 protocol (Mbus 485 → Address). When AddrnTCP parameter is set to „255”, the transducer will skip address analysis in the Modbus protocol frame (announce mode).

6. Accessories

6.1. Memory card

In case of the transducer version P30H-XX1XXXXXXXXX using SD/SDHC cards, it is possible to order industrial-grade SD cards with the capacity suited to the user's needs, as shown in the table below. **It is not recommended to use commercial-grade cards** due to high parameter differences and short life span.

Table 45

Item	Order code	Capacity
1	20-199-00-00023	1 GB
2	20-199-00-00025	2 GB

6.2. Additional resistor D5

If there is a need to measure voltages higher than 300V, D.C. one must use an external additional resistor type D5-1XX (600V) or D5-2XX (1000V). The additional resistor D5 is intended for mounting on 35mm DIN according to EN 60715.




Fig. 28 External dimensions of additional resistor D5




Fig. 29 Connection diagram of additional resistor D5

Terminal no 1...4 of slot Ra and terminals no. 5...8 of slot Rb, are internally shorted. Electrical connections must be performed with wires from 0.14 up to 1.5 mm² cross-section.

Connections of P30H and additional resistor shows figure 28.

To obtain the measurement class equal to P30H transducer's class it should be ordered D5VXX1 additional resistor version - then the resistor is scaled in a set with the transducer. Ordering codes for the additional resistor is shown in table 3 below.

Technical data:

- accuracy class 0.5;
- ambient temperature -25..23..+55 °C
- storage temperature -30..+70 °C
- humidity 25..95 % (inadmissible condensation)
- working position any
- external dimensions 22.5 x 120 x 100 mm

- weight 0.1 kg
- resistance 1.5 MΩ (D5-2XX)
0.75 MΩ (D5-1XX)

Table 46

Additional resistor D5	X	XX	X	X
Mesuring range in set with transducer P30H				
600 V	1			
1000 V	2			
Version				
Standard		00		
Custom-made		XX		
Language				
Polish			P	
English			E	
other			X	
Acceptance tests				
Without extra requirement				0
With an extra quality inspection certificate				1
Acc. to customer's request				X

Order example:

D5-200E1 means additional resistor *D5* for measuring range 1000 V, standard version, in English, with an extra quality inspection certificate.

7. Error codes

During the transducer's operation, various error messages might be displayed on the display. The table below lists the error codes which are possible to be displayed and their reasons as well as the recommended user responses.

Table 47

Message	Description
Err FRAM Service	Calibration parameters memory error - send the transducer for maintenance, message blocks the display of measured values
Err DF	Archive internal memory error - measurement archiving is not possible, transducer can operate, it is recommended to send the transducer for maintenance; message does not block the display of measured values – it is displayed in cycles.
Err Cal.	No calibration parameters - send the transducer for maintenance, message does not block the display of measured values – it is displayed in cycles.
Err Batt Service	Real Time Clock battery voltage too low – RTC settings will be deleted after the transducer is powered off, transducer can operate, it is recommended to send the transducer for battery change; message does not block the display of measured values – it is displayed in cycles, setting of date or time turns the message off.
Err Par.	Parameters error – transducer settings error, return to factory defaults, transducer can operate but it is not recommended until the factory settings are reverted, message does not block the display of measured values – it is displayed in cycles
Error File	Attempt to read the file from external SD/SDHC or file system internal memory failed – no file present, or invalid file format, transducer can operate, message does not block the display of measured values – it is cycled approx. every 20 seconds.

8. Technical data

Input:

Table 48

Measured value		Nominal range	Measuring range (maximal)	Class
Voltages (input resistance 500kΩ) U, dU, U _{AV}	U ₀₁ to R ₀₁	K_U=1, K_I=1000		
	12V	-4 ... 12 V	-5...15 V	0.2
	48V	-4 ... 48 V	-10...57.6 V	
	100V	-5 ... 100 V	-10...120 V	
	250V	-5 ... 250 V	-10 ... 300 V	
	600V*	-10 ... 500 V	-10 ... 600 V	0.2 + class of additional resistor
	1000V*	-10 ... 1000 V	-10 ... 1000 V	
Currents (shunt voltage) (input resistance 250kΩ) I, dI, I _{AV}		-15000 ... 15000 A (-150 ... 150 mV)	-18000 ... 18000 A (-180 ... 180 mV)	0.2+ shunt class (voltage measurement 0.2)
Timer t[s] t[h.m]		0...999999999 s 0...277777.5 h.m		1s/ 24h, resolution 1 s
Capacity C		-49 999 999 ... 49 999 999 kAh		±0.5 %
Power P, P _{AV}	12V	-60...180 kW	-75...225 kW	0.4 + shunt class
	48V	-60...720 kW	-150...864 kW	
	100V	-0,075...1,5 MW	-0,15...1,8 MW	
	250V	-0,075...3,75 MW	-0,15...4,5 MW	
	600 V*	-0,15...7,5 MW	-0,3...9 MW	0.4 + class of additional resistor + shunt class
	1000 V*	-0,3...15 MW	-0,6...18 MW	

Imported energy $E_{P\leftarrow}$ Exported energy $E_{P\rightarrow}$	0 ... 99 999 999.9 kWh	$\pm 0.5\%$ + shunt class
Sum of energy (imported and exported) E_T	0 ... 199 999 999.9 kWh	$\pm 1\%$ + shunt class
Difference of energy (imported and exported) E_n	-99 999 999.9 ... 99 999 999.9 kWh	$\pm 1\%$ + shunt class
K_U - voltage ratio (Primar. U / Second. U), K_I - current ratio (Shunt. I / Shunt. mV, $K_I = 100\,000$ eg. For shunt 15 000 A / 150mV)		
* - in set with additional resistor D5 ($K_U \neq 1$)		

The maximum range display of measured values on the LCD display are -999999G ... 999999G. These ranges depend upon the size parameters of the primary and secondary voltage divider and the shunt ratio (parameters Primar. U, Second. U, Shunt. I, Shunt. mV).

Outputs:

Main analog output OUT1

● analog, programmable, galvanically isolated

* current $I_{OUT} = 0/4...20$ mA, load resistance $\leq 500\ \Omega$; or

* voltage $U_{OUT} 0...10$ V, load resistance $\geq 500\ \Omega$,

● analog output class 0.1;

● processing time < 200 ms

● overload $1.2 I_{OUT}$, or $1.2 U_{OUT}$,

Additional analog output (OUT2, interchangeably with relay output)

- 1 analog output (interchangeably with alarm output)
- * current $I_{OUT} = 0/4...20$ mA, load resistance $\leq 250 \Omega$; or
- * voltage $U_{OUT} 0...10$ V, load resistance $\geq 500 \Omega$,
- class 0.5
- processing time < 500 ms
- overload $1.1 I_{OUT}$, or $1.1 U_{OUT}$,

Alarm outputs

- relay – 1 or 2 relays; volt-free NO contacts – max. load capacity 5 A 30 VDC, 250 VAC; 100 000 switching cycles

Digital output – RS-485 interface:

- transmission protocol: Modbus RTU
- address: 1...247
- mode: 8N2, 8E1, 8O1, 8N1
- baud rate: 4800, 9600, 19200, 38400, 57600, 115200, 230400, 256000 b/s
- max. response time: 200 ms ¹
- min. interval between successive queries 5 ms

Ethernet interface: 10/100-Base-T

- max. simultaneous connections 4

Power output

- auxiliary supply (optional - interchangeably with alarm output A2) 24 VDC / 30 mA.

Power consumption	<5 VA
Weight	< 0.25 kg
Dimensions	120 x 45 x 100 mm
Fixing	35 mm rail acc. to EN 60715

Protection grade ensured by the housing

from housing side (version without a support of SD/SDHC cards)
IP40

from housing side (version with a support of SD/SDHC cards)
IP30

from terminals side IP20

Readout field LCD text display 2x8 characters with LED illumination

Preheating time of the transducer 15 min

¹the response time can be extended to 500 ms while writing data to the SD card

Registration

Registration to the internal memory of 4MB (max. 534336 records) - registration with time stamp, ordering versions with the external SD/SDHC card slot allow for automatic saving the internal archive to the SD/SDHC card; ordering versions with Ethernet interface and file system internal memory allow for automatic saving the internal archive into files.

Reference and rated operating conditions

●supply voltage 85...253 V a.c (40..400 Hz)., 85...300 V d.c. or 20..40 V a.c.(40..400 Hz), 20...60 V d.c.

●ambient working temperature -25..23..+55 °C

●storage temperature -30..+70 °C

- humidity 25...95% (no condensation)
- working position any

Short-term overload (5s)

- voltage input (terminals 1,3) 1,5Un (Un_{MAX} = 250V)
- current input (terminals 3,4) 20Un (Un_{MAX} = 0,15V)

Additional errors:

- from temperature changes: for analog output 50% of class / 10 K
for measuring inputs 100% of class / 10 K

Standards compliance:**Electromagnetic compatibility:**

- Noise immunity acc. to EN 61000-6-2
- Noise emission acc. to EN 61000-6-4

Safety requirements:

according to EN 61010-1 standard

- isolation between circuits (P30H-X0XXXXXXXX, P30H-X1XXXXXXXX):
 - increased between input circuits (terminals 1-4) and remaining circuits (60s/3.51 kV a.c.) for input voltages up to 300 V d.c.
 - basic between input circuits (terminals 1-4) and remaining circuits (60s/3.51 kV a.c.) for input voltages from the range 300...1000 V d.c. (measurement with use of additional resistor D5)
 - basic between all remaining circuits (1min/2.21kV d.c.)
- isolation between circuits (P30H-X2XXXXXXXX,):
 - increased between input circuits (terminals 1-4) and remaining circuits (60s/3.51 kV a.c.) for input voltages from the range 300...1000 V d.c. (measurement with use of additional resistor D5)

- basic between all remaining circuits (1 min/2.21 kV d.c.)), save for ordering version:

P30H-X2X2XXXXXX– isolation between power output 24 VDC (terminals 11, 12) and Ethernet slot (60s/1.4 kVAC)

- Installation categorie

- III for input voltage up to 300 V d.c.,
- III for input voltage 300...600 V d.c. with additonal resistance D5,
- II for input voltage 600...1000 V d.c. with additonal resistance D5

- pollution grade 2,

- maximum phase-to-earth operating voltage: 300 V for supply and measurement circuits and 50 V for other circuits.

- altitude a.s.l. < 2000

9. Ordering code

Table 49

P30H transducer	X	X	X	X	X	X	XX	X	X
Analog output OUT1									
current (0/4...20 mA)	1								
voltage (0...10 V)	2								
Optional accessories									
none	0								
Slot of the external memory SD/SDHC	1								
Ethernet interface with internal memory file system	2								
Output OUT2									
Relay A1, 5A 30V d.c., 250V a.c.	1								
Analog current output (0/4...20 mA)	2								
Analog voltage output (0...10 V)	3								
Output OUT3									
Relay A2, 5A 30V d.c., 250V a.c.	1								
Power output 24 V d.c. / 30 mA.	2								
Supply									
85...253 V a.c., 85...300 V d.c.	1								
20...40 V a.c., 20...60 V d.c.	2								
Version									
standard	0								
custom-made *	XX								
Language									
Polish	P								
English	E								
other	X								
Quality inspection tests									
Without extra requirements	0								
Quality inspection certificate	1								
Acc. to customer's request	X								

*as per agreement with the manufacturer

Code example:

P30H-111210E1 *The code means transducer in standard version with analog current output, with external SD/SDHC card, with relay alarm no.1, with power output 24 V/30mA, with supply 85...235 V a.c./d.c., in English, with an extra quality inspection certificate.*



LUMEL S.A.

ul. Słubicka 4, 65-127 Zielona Góra, Poland
tel.: +48 68 45 75 100, fax +48 68 45 75 508
www.lumel.com.pl

Technical support:

tel.: (+48 68) 45 75 143, 45 75 141, 45 75 144, 45 75 140
e-mail: export@lumel.com.pl

Export department:

tel.: (+48 68) 45 75 130, 45 75 131, 45 75 132
e-mail: export@lumel.com.pl

Calibration & Attestation:

e-mail: laboratorium@lumel.com.pl